

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.


WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Page one

DODGE CITY SW

ACC

1. Location of well:	County FORD	Fraction 3/4 N 3/4 W 1/4 E 1/4 1/4 1/4	Section number 2	Township number T 26 S	Range number R 26 W
2. Distance and direction from nearest town or city: DODGE CITY Street address of well location if in city: 5 W 50 HWY 3 1/4 N 1/2 E			3. Owner of well: Bill & Harold Rebine R.R. or street: 1211 W. Cedar City, state, zip code: Dodge City, KS 67801		
4. Locate with "X" in section below: 			Sketch map:		
5. Type and color of material			From	To	6. Bore hole dia. 4 1/2 in. Completion date _____ Well depth 449 ft.
Surface			0	3	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
Clay			3	45	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Caliche			45	70	9. Casing: Material ST Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface _____ in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia 16 in. to 89 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____
Caliche & sand layers			70	75	10. Screen: Manufacturer's name W.A. Brown Type Bridge Dia. 16 Slot/gauze 1/8 Length _____ Set between 89 ft. and 449 ft. _____ ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 1/2 down
sand & gravel			75	78	11. Static water level: _____ mo./day/yr. 118 ft. below land surface Date _____
Cemented sand			78	85	12. Pumping level below land surfaces: 240 ft. after 2 hrs. pumping 650 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.
Cemented sand & clay			85	95	13. Water sample submitted: _____ mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____
sand & gravel			95	104	14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade
clay			104	106	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
med. sand			106	126	16. Nearest source of possible contamination: NONE ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No
clay			126	140	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
med. sand with some clay balls			140	150	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Johnson Drilling 337 Business name Box 746 License No. _____ Address _____ Signed Janis Johnson Date _____ Authorized representative
med. sand clean			150	165	
med. sand small gravel clean			165	180	
caliche & clay			180	190	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	in 08 2645 217 2410 TOPU				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Page two

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction 1/4 1/4 1/4	Section number	Township number T S R	Range number E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: <i>Rebnie Bros.</i> R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: N W E S 1 Mile			Sketch map: 6. Bore hole dia. _____ in. Completion date _____ Well depth _____ ft. 7. ___ Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored ___ Reverse rotary 8. Use: ___ Domestic ___ Public supply ___ Industry ___ Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other 9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface _____ in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. _____ in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____		
5. Type and color of material			From	To	
<i>med. sand</i>			<i>190</i>	<i>195</i>	
<i>med. sand & gravel</i>			<i>195</i>	<i>210</i>	
<i>sand & gravel</i>			<i>210</i>	<i>225</i>	
<i>sand & gravel good</i>			<i>225</i>	<i>227</i>	
<i>clay</i>			<i>227</i>	<i>232</i>	
<i>gray shale</i>			<i>232</i>	<i>236</i>	
<i>Black shale</i>			<i>236</i>	<i>240</i>	
<i>hard Rock</i>			<i>240</i>	<i>248</i>	
<i>hard Rock clay</i>			<i>248</i>	<i>251</i>	
<i>gray shale</i>			<i>251</i>	<i>258</i>	
<i>gray shale & Brown clay</i>			<i>258</i>	<i>268</i>	
<i>gray shale & some sand stone</i>			<i>268</i>	<i>274</i>	
<i>gray shale</i>			<i>274</i>	<i>289</i>	
<i>Brown sand Rock</i>			<i>289</i>	<i>293</i>	
<i>gray shale</i>			<i>293</i>	<i>295</i>	
(Use a second sheet if needed)					
18. Elevation: Topography: ___ Hill ___ Slope ___ Upland ___ Valley		19. Remarks: <i>Block 227</i> <i>118</i> <i>109' sat. thick</i>		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Business name _____ License No. _____ Address _____ Signed _____ Date _____ Authorized representative	

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction 1/4 1/4 1/4	Section number	Township number T S R	Range number E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:			3. Owner of well: <i>Rebins Bros.</i> R.R. or street: City, state, zip code:		
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E SW SE S 1 Mile</div>			Sketch map: 6. Bore hole dia. _____ in. Completion date _____ Well depth _____ ft.		
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material _____ Height: Above or below Threaded _____ Welded _____ Surface _____ in. RMP _____ PVC _____ Weight _____ lbs./ft. Dia. _____ in. to _____ ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. _____		
			10. Screen: Manufacturer's name _____ Type _____ Dia. _____ Slot/gauze _____ Length _____ Set between _____ ft. and _____ ft. _____ ft. and _____ ft. Gravel pack? _____ Size range of material _____		
			11. Static water level: _____ mo./day/yr. _____ ft. below land surface Date _____		
(Use a second sheet if needed)			12. Pumping level below land surfaces: _____ ft. after _____ hrs. pumping _____ g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield _____ g.p.m.		
			13. Water sample submitted: _____ mo./day/yr. Yes _____ No _____ Date _____		
			14. Well head completion: <input type="checkbox"/> Pitless adapter _____ Inches above grade		
			15. Well grouted? _____ With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From _____ ft. to _____ ft.		
			16. Nearest source of possible contamination: ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No		
			17. Pump: _____ Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
			Business name _____ License No. _____ Address _____ Signed _____ Date _____ Authorized representative		
			18. Elevation:		
			19. Remarks:		

Willie Hadden Test

Harold Rebein

Test Hole #1

754

0 - 3 Surface

3 - 52 Brown clay

249

52 - 60 Brown caleche clay

60 - 72 Caleche clay

72 - 81 Fine sand with cemented half medium gravel

81 - 95 Fine sand and sand rock 20% clay

95 - 102 Medium sand and gravel

102 - 111 Good loose medium gravel

111 - 118 Medium sand and gravel with 50% clay

7

118 - 122 Sandy brown clay

122 - 129 Half medium sand and fine gravel with 25% clay

7

129 - 141 Sandy brown clay

141 - 152 Brown clay 0 - % fine sand

152 - 172 Good loose half medium to medium sand and gravel

20

172 - 179 Sandy brown clay

179 - 189 Fine sand and gravel 10% clay

10

189 - 201 Medium sand and gravel

12

201 - 205 Brown sandy clay

205 - 222 Half medium to medium sand and gravel

17

222 - 230 Yellow clay

73

230 - 24 Dark blue shale

24 - 269 Light gray shale with traces of sand stone

269 - 291 Gray shale

291 - 293 Extra hard rock

293 - 3 Gray shale

3 - 5 - 365 Gray shale and traces of gray sand stone 50%

365 - 370 Hard rock stringers and gray shale

370 - 375 Good brown clay stone and rock

THE

clay and shale

Gray shale

Tan sand stone with 70% gray shale mixed

Good tan and brown sand stone 10% 15% gray shale mixed

Gray shale and red bed

[The page contains faint horizontal lines and significant noise, suggesting it was part of a document or form.]