



USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

West House #1 CDD

1. Location of well:		County Ford	Fraction SE 1/4 SE 1/4 SW 1/4	Section number #24	Township number T #26	Range number S R #26 X/W
2. Distance and direction from nearest town or city: 5 miles west of Dodge City, Kansas on Highway 50 Street address of well location if in city:				3. Owner of well: Jim Flake R.R. or street: 200 Water City, state, zip code: Dodge City, Kansas 67801		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 1-27-76 Well depth 225 ft.		
				7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material				From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Top soil & rock layers				0	15	9. Casing: Material RMP Height: Above or below 12 in. Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight 5 lbs./ft. Dia. 5 in. to 225 ft. depth Wall thickness 250 inches or Dia. 5 in. to 225 ft. depth gage No. 250
Sand, rock layers & medium sand				15	30	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot 1/8" Length 20 ft. Set between 200 ft. and 220 ft. ft. and 1" ft. Gravel pack? yes Size range of material 1"
Fine to medium sand				30	60	11. Static water level: 50 ft. below land surface Date 1-27-76
Fine sand				60	105	12. Pumping level below land surfaces: 50 ft. after 1 hrs. pumping 70 g.p.m. ft. after 1 hrs. pumping 70 g.p.m. Estimated maximum yield 90 g.p.m.
Fine sand & clay layers				105	120	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 1-27-76
Medium to coarse sand				120	225	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade
Medium coarse sand, clay & blue shale				225	240	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 7 ft. to 20 ft.
						16. Nearest source of possible contamination: None ft. 50 Direction 175° S of W Type well Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Not installed Manufacturer's name Flint & Walling Model number 10BK9 HP 1 Volts 230 Length of drop pipe 105 ft. capacity 19 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						18. Elevation:
						19. Remarks: New building site - location of sewer system not known.
						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name Box 174 Cimarron, Ks. License No. 5-25-76 Address Lawrence Crick Date 1-27-76 Signed Lawrence Crick Authorized representative

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5