


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County FORD	Fraction SW 1/4 SW 1/4 SE 1/4	Section number 25	Township number T 26 26 S	Range number R 25 26 E
2. Distance and direction from nearest town or city: 3 miles West Dodge City, ks			3. Owner of well: R J Knowles R.R. or street: Lewis Addition City, state, zip code: Dodge City, Ks 67801			
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 8 in. Completion date 12-23-77 Well depth 170 ft.		
				7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
Soil		0		3		9. Casing: Material Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 18" in. RMP <input type="checkbox"/> PVC Glue Weight 150 lbs./ft. Dia. 5 in. to 170 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250
Sandy loam		3		10		10. Screen: Manufacturer's name Jess & Lowell Type Plastic Dia. 5" Slot 1/16 Length 30' Set between 140 ft. and 170 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes size range of material 1/4"
Gravel		10		50		11. Static water level: <input type="checkbox"/> mo./day/yr. 10 ft. below land surface Date 12-23-77
Clay & sand		50		130		12. Pumping level below land surfaces: N/A ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
Gravel		130		(170)		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
BROCK 170		170		170		14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 18 inches above grade
160 sat. thick		160		160		15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 2 ft. to 20 ft.
						16. Nearest source of possible contamination: ft. 106' Direction W Type septic Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
						17. Pump: Manufacturer's name Dempster Not installed Model number 2120052 HP 2 Volts 230 Length of drop pipe 105 ft. capacity 51 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Cragg Well Drilling 111 Business name License No. Address 1308 So Second Dodge City Signed Ray Oling Date 12/23/77 Authorized representative		
Level Topography: <input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley		2521 170 235				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5