

1 LOCATION OF WATER WELL: Fraction Section Number Township Number Range Number
 COUNTY: FORD SE 1/4 SE 1/4 SE 1/4 17 T 26 S R 26 W

Distance and direction from nearest town or city street address of well if located within city?

FROM HOWELL 1/4 SOUTH & 1/4 WEST

2 WATER WELL OWNER: DODGE CITY SAND COMPANY
 RR#, St. Address, Box #: PO BOX 430 Board of Agriculture, Division of Water Resources
 City, State, ZIP code: DODGE CITY, KS 67801- Application Number:

3 LOCATE WELL'S LOCATION WITH
 AN "X" IN SECTION BOX:

	NW		NE
	SW		SE

4 DEPTH OF COMPLETED WELL 185 ELEVATION: 0
 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.

WELL'S STATIC WATER LEVEL 43 ft. below land surface measured on mo/day/yr 08/26/05

Pump test data: Well water was 0 ft. after 0 hours pumping 0 gpm

Estimated Yield 150 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm

Bore Hole Diameter 12 in. to 185 ft., and in. to 0 ft.

WELL WATER TO BE USED AS: INDUSTRY

Was a chemical/bacteriological sample submitted to department? No ;

If yes, mo/day/yr sample was submitted Water well disinfected? Yes

5 TYPE OF BLANK CASING USED: PVC CASING JOINTS: GLUED
 Blank casing diameter 8 in. to 185 ft., Dia in. to 0 ft., Dia in. to 0 ft.
 Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21
 TYPE OF SCREEN OR PERFORATION MATERIAL: PVC
 SCREEN OR PERFORATION OPENINGS ARE: SAW CUT

SCREEN PERFORATED INTERVALS: From 140 ft. to 180 ft., From 0 ft. to 0 ft.

From 0 ft. to 0 ft., From 0 ft. to 0 ft.

GRAVEL PACK INTERVALS: From 20 ft. to 50 ft., From 0 ft. to 0 ft.

From 60 ft. to 185 ft., From 0 ft. to 0 ft.

6 GROUT MATERIAL BENTONITE

Grout Intervals: From 0 ft. to 20 ft., From 50 ft. to 60 ft., From 0 ft. to 0 ft.

What is the nearest source of possible contamination: NONE

Direction from well?

How many feet? 0

FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS
0	20	01 TOPSOIL 05 CLAY 06 SMALL GRAVEL			
20	40	37 FIN-COAR SAN 38 SMALL-MED GRA			
40	60	05 CLAY			
60	100	32 TAN CLAY			
100	120	32 TAN CLAY 02 FINE SAND			
120	140	37 FIN-COAR SAN			
140	160	37 FIN-COAR SAN 06 SMALL GRAVEL			
160	180	37 FIN-COAR SAN 06 SMALL GRAVEL			
180	200	05 CLAY 07 BLUE SHALE			

CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 08/29/06 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 09/03/05 under the business name of JOE'S WELL SERVICE, INC. by (signature) *Judith Creek*