

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Well #1 -- House

1. Location of well:	County	Fraction	Section number	Township number	Range number
1. Location of well:	County Gray	Fraction SE 1/4 SE 1/4 NW 1/4	Section number 17	T 26	S R 27 E/W
2. Distance and direction from nearest town or city:	1/2 mile south & 2 miles east of Cimarron on highway 23		3. Owner of well:	Clarence Crick	
Street address of well location if in city:			R.R. or street:		
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia. 8 in. Completion date _____ Well depth 185 ft. 6-7-78		
					7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input checked="" type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil & Coarse sand	0	15	9. Casing: Material RMP Height: Above ground Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 6 5/8 to 185 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth gage No. 320		
Coarse sand	15	30	10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 6 5/8" Slot size 1/8" Length 20 ft. Set between 160 ft. and 180 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1"		
Coarse sand (3 ft.) & clay	30	45	11. Static water level: mo./day/yr. 10 ft. below land surface Date 6-7-78		
Clay & fine sand layers	45	105	12. Pumping level below land surfaces: 25 ft. after 1 hrs. pumping 100 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 125 g.p.m.		
Fine sand	105	135	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Fine sand & medium sand	135	150	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Medium to coarse sand	150	165	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 6 ft. to 30 ft.		
Coarse sand	165	180	16. Nearest source of possible contamination: none ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Coarse sand (5 ft.) & clay	180	190	17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Joe's Well Service 179 Business name _____ License No. _____ Address Box 174 Cimarron, Ks. Signed <input checked="" type="checkbox"/> Tony Crick 10-2-78 Date _____ Authorized representative _____		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					