

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
Gray		NE 1/4 NE 1/4 NE 1/4	#17	T #26	S R #27 W
2. Distance and direction from nearest town or city: 1 mile south and 2 1/2 miles east of Cimarron, Ks. Street address of well location if in city:	3. Owner of well: Clarence Crick R.R. or street: City, state, zip code: Cimarron, Kansas 67835				
4. Locate with "X" in section below: N	Sketch map: 				
6. Bore hole dia. 8 in. Completion date 10-22-75 Well depth 185 ft.					
7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary					
8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other					
9. Casing: Material RMP Height: Above or <input checked="" type="checkbox"/> Below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC Weight lbs./ft. Dia. 5 in. to 185 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 250					
10. Screen: Manufacturer's name Jess & Lowell Type RMP Dia. 5" Slot/gauze 1/8" Length 20 ft. Set between 160 ft. and 180 ft. ft. and ft. Gravel pack? yes Size range of material 1/4"					
11. Static water level: mo./day/yr. 15 ft. below land surface Date 10-22-75					
12. Pumping level below land surfaces: 15 ft. after 2 hrs. pumping 60 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 60 g.p.m.					
13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date					
14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade					
15. Well grouted? yes With: <input checked="" type="checkbox"/> Neg cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 5 ft. to 15 ft.					
16. Nearest source of possible contamination: ft. 50 Direction east Type lot Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
17. Pump: Not installed Manufacturer's name Flint & Walling Model number 10RK9 HP 15 Volts 230 Length of drop pipe 117 ft. capacity 19 g.p.m. Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					
19. Remarks: (Use a second sheet if needed)					
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business Name <input type="checkbox"/> License No. Address Box 174 Cimarron, Kans. Signed <i>Clarence Crick</i> Date 12-20-75 Authorized representative					