

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

**WATER WELL RECORD**  
**KSA 82a-1201-1215**

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 NE 1/4 NW 1/4	Section number 20	Township number T 26	Range number S R 27
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/2 miles south and 2 miles east and 1/2 miles south of Cimarron, Kansas		3. Owner of well: R.R. or street: City, state, zip code:	Elden Smith Cimarron, Kansas 67835	
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 8 in. Completion date 8-27-77 Well depth 220 ft. 7. <input checked="" type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight lbs./ft. Dia. 5 in. to 220 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 250		
5. Type and color of material		From	To	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot size 1/8" Length 20 ft. Set between 205 ft. and 215 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/4"	
Top soil & medium sand		0	15	11. Static water level: 47 ft. below land surface Date 8-27-77	
Medium to coarse sand		15	45	12. Pumping level below land surfaces: 50 ft. after 15 hrs. pumping 60 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 75 g.p.m.	
Medium to coarse sand & clay		45	60	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date	
Clay & fine sand		60	75	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade	
Clay layers & fine sand		75	90	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 7 ft. to 17 ft.	
Clay		90	105	16. Nearest source of possible contamination: ft. 100 Direction SE Type Sewer Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Clay & medium sand		105	120	17. Pump: Manufacturer's name Flint & Walling Model number 20BK16 HP 2 Volts 230 Length of drop pipe 147 ft. capacity 20 g.p.m.	
Clay		120	150	Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
Clay & fine to medium sand		150	165	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Joe's Well Service</b> 179 Business name <b>Box 174 Cimarron, KS.</b> License No. Address <b>Box 174 Cimarron, KS.</b> Signed <b>Larry Creek</b> Date <b>10-6-77</b> Authorized representative	
(Use a second sheet if needed)					
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5