

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray County	Fraction 1/4 NW 1/4 NW 1/4	Section number 23	Township number T 26	Range number S R 27	E 11W
2. Distance and direction from nearest town or city: 6 East on River Road 30 South of Cimarron Street address of well location if in city:			3. Owner of well: John Jillie R.R. or street: Rt. 1 City, state, zip code: Cimarron, KS 67835			
4. Locate with "X" in section below: <div style="text-align: center;">N 1 Mile W E SW SE S 1 Mile</div>			Sketch map: <div style="text-align: center;">NW NE SE SW</div>			
5. Type and color of material			6. Bore hole dia. 26 in. Completion date 9-19-77 Well depth 211 ft.			
			7. Cable tool ___ Rotary ___ Driven ___ Dug ___ Hollow rod ___ Jetted ___ Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: Domestic ___ Public supply ___ Industry ___ <input checked="" type="checkbox"/> Irrigation ___ Air conditioning ___ Stock ___ Lawn ___ Oil field water ___ Other ___			
			9. Casing: Material <u>Steel</u> Height: Above or below Threaded ___ Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP ___ PVC ___ Weight 36.87 lbs./ft. Dia. 16 in. to 211 ft. depth Wall Thickness: inches or Dia. ___ in. to ___ ft. depth gage No. 219			
			10. Screen: Manufacturer's name Johnson Type Johnson Galv-Dia. 100-16" Slot/gauze 0-70 Plain length 70-180 Perf. Set between 180-200 screen 200-211 Perf. ft. and ___ ft. Gravel pack? yes Size range of material 3 to 5/8			
			11. Static water level: mo./day/yr. 52 ft. below land surface Date 8-8-77			
			12. Pumping level below land surfaces: 74 ft. after 2 hrs. pumping 1100 g.p.m. 84 ft. after 4 hrs. pumping 1700 g.p.m. Estimated maximum yield 1700 g.p.m.			
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No ___ Date ___			
			14. Well head completion: Pitless adapter 1 ft. inches above grade			
			15. Well grouted? yes With: Neat cement ___ Bentonite <input checked="" type="checkbox"/> Concrete ___ Depth: From 0 ft. to 10 ft.			
16. Nearest source of possible contamination: ft. Direction N/A Type ___ Well disinfected upon completion? Yes ___ No ___						
17. Pump: Not installed Manufacturer's name Gould 2 stg. 14" Bowl Model number ___ HP 100 Volts ___ Length of drop pipe 160 ft. capacity 1500 p.m. Type: ___ Submersible <input checked="" type="checkbox"/> Turbine ___ Jet ___ Reciprocating ___ Centrifugal ___ Other ___						
18. Elevation:			19. Remarks:			
Topography: <input checked="" type="checkbox"/> Hill ___ Slope ___ Upland ___ Valley			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drlg. Co. 208 Business name License No. 67846 Address Box A, Garden City, KS Signed [Signature] Date 1-19-79 Authorized representative			

(Use a second sheet if needed)

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

MI-1023

The Professionals

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

JOHN JILLIE
GRAY COUNTY
7-14-77

Location: NW 23-26-27 6 miles east of Cimarron on river
road 30 ft. south of fence

Static Water Level- 30'

Test #1

0	8	Fine sand
8	32	Fine to med. sand and gravel
32	66	Brown clay
66	79	Fine to med. sand and gravel Tight
79	147	Brown sandy clay
147	203	Fine to med. sand and gravel brown and yellow rock (Loose)
203	211	Brown and yellow clay and brown and yellow rock
211	215	Shale

70 Plain
110 Perf
20 Screen
11 Perf

T.D. 211