

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
GRAY	SW 1/4 NE 1/4 SW 1/4	29	T	26	S R 27 F/N
2. Distance and direction from nearest town or city:	3 south 2 1/2 east	3 miles from well:	Louis Berry		
Street address or location if in city:	Cimarron, KS 67835				
3. R.R. or street:					
4. Locate with "X" in section below:					
5. Type and color of material	From	To			
6. Bore hole dia. 26 in. Completion date 5-31-76	Well depth	247 ft.			
7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input checked="" type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary	8. Use:	<input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry	<input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock	<input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
9. Casing: Material <input checked="" type="checkbox"/> Steel <input type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> R/W <input type="checkbox"/> PVC <input type="checkbox"/> W/S <input type="checkbox"/> Wall thickness: 12 in.	Height:	Above or below	10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division	Dia. 16 in. to 248. depth 16 ft. Wall thickness: inches or	lbs./ft.
Slot/gauge 100	Length	16' 20"	Type Galv.	Dia. 16" 20"	
Set between 220 ft. and 240 ft.	Perf.	100-220 ft. and 240-247 ft.	Size range of material	12"	Down
11. Static water level: 47 ft. below land surface	Date	5-20-76	mo./day/yr.		
12. Pumping level below land surfaces: 58 ft. after 3 hrs. pumping 1525 g.p.m.					
ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m.					
Estimated maximum yield 1525 g.p.m.					
13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>					
14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> 12 inches above grade					
15. Well grouted? <input checked="" type="checkbox"/> Yes	With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete	Depth: From <input type="checkbox"/> 0 ft. to <input type="checkbox"/> 10 ft.	Type <input type="checkbox"/>		
16. Nearest source of possible contamination: <input type="checkbox"/> N/A	ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/>	Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
17. Pump: <input type="checkbox"/> Not installed	Manufacturer's name <input type="checkbox"/> Wilson Drilling <input type="checkbox"/> 12JFH810-100 Pump <input type="checkbox"/>	Model number <input type="checkbox"/> 12JFH810 HP <input type="checkbox"/> 100 Volts <input type="checkbox"/>	Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Jet <input type="checkbox"/> Centrifugal	<input type="checkbox"/> Turbine <input type="checkbox"/> Reciprocating <input type="checkbox"/> Other	
Length of drop pipe 140 ft. capacity 1000 gpm.					
18. Elevation: <input type="checkbox"/> (Use a second sheet if needed)	19. Remarks: <input type="checkbox"/>	<p>This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.</p> <p>Minister Wilson Drilling 208 Business name P.O. Box A Garden City, KS Address Signed <input type="checkbox"/> Date 22-2-76 Authorized representative <input type="checkbox"/> Date <input type="checkbox"/></p>			

Forward the white, blue and pink copies to the Department of Health and Environment

MINTER-WILSON DRILLING CO. INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

LOUIS BEHN
Gray County
4-28-76

Location: SW 29-26-27 South of Cimarron Bridge 3 Miles South
2 1/4 Miles East 1/4 Mile North
Static Water Level: -70

Test #1

0	1	Top Soil
1	35	Brown Sandy Clay
35	100	Fine To Med. Sand and Gravel Loose
100	112	Med. Sand and Med To Coarse Gravel Loose
112	155	Fine To Med. Sand and Gravel Streaks of Clay 100
155	180	Brown Clay and Fine Sand Mixture No Good
180	230	Fine To Med. Sand and Gravel Loose
230	247	Fine To Med. Sand and Gravel With White and Yellow Rock Loose
247	251	Shale

ID 247
Screen