

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	GRAY	NW $\frac{1}{4}$ SE $\frac{1}{4}$ NW $\frac{1}{4}$	29	T 26 S R	27 NW
2. Distance and direction from nearest town or city:	3 south 2 east 3/4 north $\frac{1}{4}$ east of Cimarron Bridge		3. Owner of well:	Louis Berry	
Street address of well location if in city:			R.R. or street:	Cimarron, KS 67835	
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia.	26	in. Completion date 5-31-76
			Well depth	252	ft.
5. Type and color of material	From	To	7. Cable tool	Rotary	Driven Dug
			Hollow rod	Jetted	Bored Reverse rotary
			8. Use:	Domestic	Public supply
			Irrigation	Air conditioning	Industry
			Lawn	Oil field water	Stock
					Other
			9. Casing: Material	Steel	Height: Above or below
			Threaded	Welded	Surface 12 in.
			RMP	PVC	Weight 6.87 lbs./ft.
			Dia.	16 in. to 253 ft. depth	Wall Thickness: inches or
			Dia.	in. to ft. depth	gage No.
			10. Screen: Manufacturer's name		
			Johnson Division		
			Type	Galv.	Dia. 16"
			Slot/gauze	100	Length 20 ft.
			Set between	220 ft. and 240 ft.	
			Ref.	100-220 ft. and 240-252 ft.	
			Gravel pack?	yes	Size range of material $\frac{1}{2}$ " Down
			11. Static water level:	mo./day/yr.	
			56 ft. below land surface	Date 5-25-76	
			12. Pumping level below land surfaces:		
			81 ft. after 3 hrs. pumping	1500 g.p.m.	
			ft. after hrs. pumping	g.p.m.	
			Estimated maximum yield	1500 g.p.m.	
			13. Water sample submitted:	mo./day/yr.	
			Yes	No	Date
			14. Well head completion:		
			Pitless adapter	12 inches above grade	
			15. Well grouted?	yes	
			With:	Neat cement	Bentonite
			Depth: From	0 ft. to 10 ft.	Concrete
			16. Nearest source of possible contamination:	N/A	
			ft.	Direction	Type
			Well disinfected upon completion?	Yes	No
			17. Pump:	Not installed	
			Manufacturer's name	Goulds US Pumps	
			Model number	12 JHO	HP 100 Volts
			Length of drop pipe	140 ft.	capacity 1000 g.p.m.
			Type:		
			Submersible	Turbine	
			Jet	Reciprocating	
			Centrifugal	Other	
18. Elevation:	(Use a second sheet if needed)		19. Remarks:	20. Water well contractor's certification:	
Topography:				This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.	
<input type="checkbox"/> Hill				MinterWilson Drilling 208	
<input checked="" type="checkbox"/> Slope				Business name	License No.
<input type="checkbox"/> Upland				Address	P.O. Box A Garden City, KS
<input type="checkbox"/> Valley				Authorized representative	Date 5-27-76

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

Revised

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

LOUIS HISTOLOGY
Gray County
5-10-76

Location: 29-26-27 35 T. South of Miville
Static Water Level-70

Test #

0	2	Top Soil
1	15	Brown Sandy Clay
15	35	Fine To Med. Sand Loose
35	102	Med. Sand To Coarse Gravel Loose
102	116	Light Brown Clay
116	125	Fine To Med. Sand and Gravel
125	240	Fine To Med. Sand loose
140	161	Fine To Med. Sand and Gravel 10% Clay
161	168	Brown Sandy Clay
168	182	Brown Sandy Clay Sand Streaks
182	252	Fine To Med. Sand Gravel Mixed Yellow White Rock Loose
252	254	Yellow Clay
254	255	Shale

TD 252
Screen