

USE TYPEWRITER OR BALL
POINT PEN, PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 SE 1/4	Section number 30	Township number T 26 S R 27	Range number 27
2. Distance and direction from nearest town or city: Street address of well location if in city:	3 south, 3 east, 1/4 south, 1/4 southeast of Cimarron		3. Owner of well: R.R. or street: City, state, zip code: Terry Nolan Cimarron, Ks. 67885		
4. Locate with "X" in section below: Sketch map:			Sketch map: 6. Bore hole dia. 26 in. Completion date 7-11-77 Well depth 248 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP 16 ft./sec. PVC 36.87 lbs./ft. Dia. 16 in. to 249 ft. depth Wall Thickness: inches or Dia. 16 in. to 249 ft. depth gage No. .250		
			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot 1/4" Length 20 ft. Set between 220 ft. and 240 ft. Perf: 100-220 ft. and 240-248 ft. Gravel pack? yes Size range of material 1" down		
			11. Static water level: 67 ft. below land surface Date 5-20-76 mo./day/yr.		
			12. Pumping level below land surfaces: 100 ft. after 3 hrs. pumping 750 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 750 g.p.m.		
			13. Water sample submitted: no Date mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. 0 Direction 0 Type 0 Well disinfected upon completion? yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
			17. Pump: Not installed Manufacturer's name Goulds - US Pump Model number 12JNC HP 100 Volts 110 Length of drop pipe 140 ft. capacity 750 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name Box A Garden City, Ks. License No. Address 11-29-77 Signature John Minter Date 11-29-77 Authorized representative John Minter		

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

TERRY NOLAN
GRAY COUNTY
3/22/77

Location: 30-26-27 3½ mile south of Cimarron, 2 east, ½
north, ¼ west of pivot

Static Water Level- 70'

Test #1

0	4	Top soil
4	33	Brown sandy clay
33	153	Fine to med. sand and gravel
153	171	Brown clay
171	248	Fine to med. sand and gravel
248	253	Brown and yellow clay
253	260	Shale

T.D. 248
Screen