

1 LOCATION OF WATER WELL: COUNTY: GRAY	Fraction SE 1/4 SE 1/4 NE 1/4	Section Number 30	Township Number T 26 S	Range Number R 27 W																																																												
Distance and direction from nearest town or city street address of well if located within city? FROM CIMARRON - 4 MILES SOUTH ON HIGHWAY 23 2 M EAST & 1/2 M																																																																
2 WATER WELL OWNER: CARL LEATHERWOOD RR#, St. Address, Box # : City, State, ZIP code : CIMARRON, KS 67835- Board of Agriculture, Division of Water Resources Application Number:																																																																
3 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:		4 DEPTH OF COMPLETED WELL 265 ELEVATION: 0 Depth(s) Groundwater Encountered 1. 0 ft. 2. 0 ft. 3. 0 ft.																																																														
<div style="display: flex; align-items: center;"> <div style="writing-mode: vertical-rl; transform: rotate(180deg); margin-right: 5px;">1 mile</div> <table border="1" style="border-collapse: collapse; text-align: center;"> <tr><td> </td><td>NW</td><td>NE</td></tr> <tr><td>W</td><td></td><td>X</td></tr> <tr><td> </td><td>SW</td><td>SE</td></tr> </table> </div>			NW	NE	W		X		SW	SE	WELL'S STATIC WATER LEVEL 120 ft. below land surface measured on mo/day/yr 09/17/92 Pump test data: Well water was 0 ft. after 0 hours pumping 0 gpm Estimated Yield 80 gpm: Well water was 0 ft. after 0 hours pumping 0 gpm Bore Hole Diameter 8 in. to 265 ft., and in. to 0 ft.																																																					
			NW	NE																																																												
		W		X																																																												
			SW	SE																																																												
WELL WATER TO BE USED AS: DOMESTIC																																																																
Was a chemical/bacteriological sample submitted to department? No ; If yes, mo/day/yr sample was submitted Water well disinfected? Yes																																																																
5 TYPE OF BLANK CASING USED: PVC CASING JOINTS: GLUED Blank casing diameter 5 in. to 265 ft., Dia in. to 0 ft., Dia in. to 0 ft. Casing height above land surface 12 in., weight 200 lbs/ft. Wall thickness or gauge No. 21 TYPE OF SCREEN OR PERFORATION MATERIAL: PVC SCREEN OR PERFORATION OPENINGS ARE: SAW CUT																																																																
SCREEN PERFORATED INTERVALS: From 220 ft. to 260 ft., From 0 ft. to 0 ft. From 0 ft. to 0 ft., From 0 ft. to 0 ft. GRAVEL PACK INTERVALS: From 20 ft. to 265 ft., From 0 ft. to 0 ft. From 0 ft. to 0 ft., From 0 ft. to 0 ft.																																																																
6 GROUT MATERIAL BENTONITE Grout Intervals: From 0 ft. to 20 ft., From 0 ft. to 0 ft., From 0 ft. to 0 ft. What is the nearest source of possible contamination: NONE - NEW SITE Direction from well? How many feet? 0																																																																
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 10%;">FROM</th> <th style="width: 10%;">TO</th> <th style="width: 40%;">LITHOLOGIC LOG</th> <th style="width: 10%;">FROM</th> <th style="width: 10%;">TO</th> <th style="width: 20%;">PLUGGING INTERVALS</th> </tr> </thead> <tbody> <tr><td>0</td><td>20</td><td>TOPSOIL FINE SAND</td><td></td><td></td><td></td></tr> <tr><td>20</td><td>40</td><td>FINE SAND</td><td></td><td></td><td></td></tr> <tr><td>40</td><td>80</td><td>FINE - MED SAND</td><td></td><td></td><td></td></tr> <tr><td>80</td><td>132</td><td>FINE - MED SAND SMALL GRAVEL</td><td></td><td></td><td></td></tr> <tr><td>132</td><td>136</td><td>CLAY</td><td></td><td></td><td></td></tr> <tr><td>136</td><td>80</td><td>CLAY FINE SAND IN LAYERS</td><td></td><td></td><td></td></tr> <tr><td>180</td><td>215</td><td>MED-COARSE SAND SMALL GRAVEL</td><td></td><td></td><td></td></tr> <tr><td>215</td><td>265</td><td>MED-COARSE SAND SMALL GRAVEL</td><td></td><td></td><td></td></tr> <tr><td>265</td><td>0</td><td>CLAY</td><td></td><td></td><td></td></tr> </tbody> </table>					FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS	0	20	TOPSOIL FINE SAND				20	40	FINE SAND				40	80	FINE - MED SAND				80	132	FINE - MED SAND SMALL GRAVEL				132	136	CLAY				136	80	CLAY FINE SAND IN LAYERS				180	215	MED-COARSE SAND SMALL GRAVEL				215	265	MED-COARSE SAND SMALL GRAVEL				265	0	CLAY			
FROM	TO	LITHOLOGIC LOG	FROM	TO	PLUGGING INTERVALS																																																											
0	20	TOPSOIL FINE SAND																																																														
20	40	FINE SAND																																																														
40	80	FINE - MED SAND																																																														
80	132	FINE - MED SAND SMALL GRAVEL																																																														
132	136	CLAY																																																														
136	80	CLAY FINE SAND IN LAYERS																																																														
180	215	MED-COARSE SAND SMALL GRAVEL																																																														
215	265	MED-COARSE SAND SMALL GRAVEL																																																														
265	0	CLAY																																																														
7 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was Constructed under my jurisdiction and was completed on (mo/day/year) 09/17/92 and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179 This Water Well Record was completed on (mo/day/yr) 10/14/92 under the business name of JOE'S WELL SERVICE, INC. by (signature) <i>Joe's Well Service</i>																																																																