


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66420

1. Location of well: Gray	County	Fraction (Pivot) SE 1/4 NW 1/4 NW 1/4	Section number 33	Township number T 26 S R 27 E	Range number E
2. Distance and direction from nearest town or city: 4 south, 4 east, 1/4 south, 3/4 west of Cimarron, Ks. Street address of well location if in city:	3. Owner of well: R.R. or street: City, state, zip code: Terry Nolan Cimarron, Ks. 67835				
4. Locate with "X" in section below: 	Sketch map:		6. Bore hole dia. 26 in. Completion date 7-17-75 Well depth 229 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input checked="" type="checkbox"/> Steel Height: Above surface Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 30.07 lbs./ft. Dia. 16 in. to 230 ft. depth Well Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gauge No.		
			10. Screen: Manufacturer's name <input checked="" type="checkbox"/> Johnson Division Type Galv. Dia. 16" Slot <input type="checkbox"/> Length 20' Set between 133 ft. and 153 ft. ft. and <input type="checkbox"/> ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <input type="checkbox"/> down		
			11. Static water level: mo./day/yr. 49 ft. below land surface Date 7-22-75		
			12. Pumping level below land surfaces: 23 ft. after 2 hrs. pumping 190 g.p.m. 50 ft. after 4 hrs. pumping 1342 g.p.m. Estimated maximum yield 1300 g.p.m.		
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: Pitless adapter 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name <input checked="" type="checkbox"/> Peerless - FMC Model number 4742 HP 100 Volts Length of drop pipe 140 ft. capacity 1300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling, Co. 209 Business name <input type="checkbox"/> License No. Address Box 493 Garden City, Ks. Signature <input type="checkbox"/> Authorized representative Date 7-22-75		
18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:				

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

TEST NO. 2

4 FILES SOUTH OF CIMARRON, 4 MILES EAST, $\frac{1}{4}$ MILE SOUTH,
 $\frac{3}{4}$ MILE WEST PIVOT.

NW $\frac{1}{4}$ 33-26-27 SEC
 TRACK
 RANGE

0	-	2	FINE SAND	GRAY CO. 3/20/75
2	-	6	TOP SOIL	
3	-	17	BROWN SANDY CLAY	
37	-	100	COARSE GRAVEL (LOOSE) MIXED WITH ROCK (SMALL STREAK CLAY)	
100	-	153	COARSE GRAVEL (LOOSE) MIXED WITH ROCK	
153	-	179	GRAY CLAY (HARD)	
179	-	209	FINE TO MED SAND (LOOSE) SMALL STREAK CLAY	
209	-	226	BROWN SANDY CLAY (SMALL BARD STREAK)	
226	-	229	FINE TO MED SAND AND GRAVEL (LOOSE) MIXED WITH BROWN AND WHITE ROCK	
229	-	235	BROWN CLAY	
235	-	240	BROWN SANDY CLAY	
240	-	246	BROWN CLAY	
246	-	248	YELLOW CLAY	
248	-	250	BLUE SHALE	

Jerry Nolan

229
 153
 16