


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 33	Township number T 26 S	Range number R 27 NW
2. Distance and direction from nearest town or city: 3 south of the Cimarron bridge, 3 east, 3/4 south, Street address of well location if in city: $\frac{1}{4}$ east, 30' N. of pivot	3. Owner of well: R.R. or street: City, state, zip code:		Terry Nolan Rt. 1 Cimarron, Ks. 67835		
4. Locate with "X" in section below: 	Sketch map:		6. Bore hole dia. 26 in. Completion date 9-30-76 Well depth 256 ft.		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input type="checkbox"/> steel <input type="checkbox"/> iron <input type="checkbox"/> aluminum Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 25.7 ft. depth! Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth <input type="checkbox"/> gage No. 250 MN		
			10. Screen: Manufacturer's name Johnson Type <input type="checkbox"/> galv. <input type="checkbox"/> Dia. 16" Slot/gauze <input type="checkbox"/> Length 20 ft. Set between 230 ft. and 250 ft. Perf: 100-230 ft. and 250-256 ft. Gravel pack? <input checked="" type="checkbox"/> yes Size range of material $\frac{1}{2}$ " down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 71 ft. below land surface Date 6-18-76		
			12. Pumping level below land surfaces: 112 ft. after 3 hrs. pumping 900 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> 900 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter <input type="checkbox"/> 12 inches above grade		
			15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds - US Pump Model number 12JHC HP 100 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
	19. Remarks: (Use a second sheet if needed)		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> Address Box A Garden City, Ks. <input type="checkbox"/> Signed <input type="checkbox"/> Date <input type="checkbox"/> Authorized representative <input type="checkbox"/>		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-6

WILSON DRILLING CO. INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

TERRY NOLAN
GRAY COUNTY
4-27-76

Location: S.W. 33-26-27

From bridge south of Cimarron, 3 miles South, 3 miles East, 3/4 mile South, $\frac{1}{2}$ mile East, 30 feet North of Pivot.

Static Water Level: 70'

Test # 1

0	3	Top Soil
3	22	Brown Sandy Clay
22	35	Fine Sand
35	63	Brown Clay
63	112	Fine to Med. Sand & Gravel (Loose)
112	140	Fine to Med. Sand & Gravel, Streaks of Clay (10%)
140	167	Fine to Med. Sand & Gravel (Loose)
167	169	White & Yellow Rock (Loose)
169	180	Brown Sandy Clay, Streaks of Fine Sand (20%)
180	187	Fine to Med. Sand, Streaks of Clay (10%)(Loose)
187	209	Fine to Med. Sand & Fine Gravel, Small Streaks of Clay (Loose)(10%)
209	230	Brown Sandy Clay
230	256	Yellow Clay
256	260	Shale