


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 7	Township number T 26 S R 28 E/W	Range number
2. Distance and direction from nearest town or city: 1 1/2 South of Cimarron bridge, 4 3/4 West, 1 1/2 North Street address of well location if in city:				3. Owner of well: Charles Thomas R.R. or street: City, state, zip code: Cimarron, KS 67835		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. 26 in. Completion date 7-28-76 Well depth 201 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
						9. Casing: Material Steel Height: Above 12 in. Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36-87 lbs./ft. Dia. 16 in. to 202 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>
						10. Screen: Manufacturer's name Johnson Type Galvanized Dia. 16" Slot/pipe 100 Length 20' Set between 170 ft. and 190 ft. Perf: 80-170 ft. and 190-201 ft. Gravel pack? Yes Size range of material 3" Down
						11. Static water level: <input type="checkbox"/> mo./day/yr. 38 ft. below land surface Date 4-7-76
						12. Pumping level below land surfaces: 56 ft. after 3 hrs. pumping 1475 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1475 g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date <input type="checkbox"/>
						14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
						15. Well grouted? Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.
						16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds-US Pump Model number 12" HP 125 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
						(Use a second sheet if needed)
18. Elevation:		19. Remarks:		20. Water well contractor's certification:		
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Drilling done by: Central Well & Pump Pratt, KS		This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name License No. Address Box A, Garden City, KS Signed <i>[Signature]</i> Date 8-12-76 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
3-9-76

LOCATION: SW 7-26-28
Offset, 600' East Of Pivot 29

STATIC WATER LEVEL: 50'

TEST #3 29B

0	1	Top Soil
1	14	Fine Sand, Some Coarse Gravel
14	25	Brown Sandy Clay
25	36	Fine To Med. Sand & Gravel
36	55	Brown Sandy Clay
55	65	Fine To Med. Sand & Gravel (10%) Clay
65	69	Fine To Med. Sand & Gravel (Loose)
69	74	Brown Sandy Clay
74	80	Fine To Med. Sand & Gravel, Clay Streak
80	96	Fine To Med. Sand & Gravel (Loose)
96	132	Brown Sandy Clay
132	155	Fine To Med. Sand
155	194	Med. To Coarse Gravel Mixed With Brown, Yellow (Loose)
194	201	Med. To Coarse Gravel Mixed With Brown, Yellow (Little Tight)
201	206	Yellow Clay (Hard)
206	208	Shale
TD	201	
	80'	Plain
	90'	Perf.
	20'	Screen
	<u>11'</u>	Perf.