

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

CORRECTED COPY

1. Location of well:	County Gray	Fraction SE 1/4 SE 1/4 NW 1/4	Section number #11	Township number #26	Range number #28 NW
2. Distance and direction from nearest town or city:	West edge of town on Highway 50.		3. Owner of well: R.R. or street: City, state, zip code:	Waits Homegas % Bud Byers Cimarron, Kansas 67835	
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. 180 in. Completion date 7-25-75 Well depth 8 ft.	
			7. Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Top soil & clay	0	15	9. Casing: Material RMP <input type="checkbox"/> Height: Above ground Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight lbs./ft. Dia. 5 in. to 180 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 250		
Clay & coarse sand	15	30	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot/gauze 1/8" Length 20 ft. Set between 155 ft. and 175 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1"		
Coarse sand	30	45	11. Static water level: mo./day/yr. 48 ft. below land surface Date 7-25-75		
Coarse sand & clay	45	60	12. Pumping level below land surfaces: 72 ft. after 2 hrs. pumping 80 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 125 g.p.m.		
Clay	60	75	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Clay layers & fine sand	75	90	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade		
Fine sand	90	120	15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 10 ft. to 20 ft.		
Fine sand to medium sand	120	135	16. Nearest source of possible contamination: Fertilizer ft. 70 Direction South Type Plant Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Medium sand & clay	135	150	17. Pump: Manufacturer's name Flint & Walling Model number 10BK9 HP 1 Volts 230 Length of drop pipe 105 ft. capacity 19 g.p.m.		
Clay & coarse sand	150	165	Type: <input checked="" type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
Coarse sand & clay	165	180	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name <input type="checkbox"/> License No. Address Box 174 Cimarron, Ks. Signed <input type="checkbox"/> Date 9-4-75 Authorized representative		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					