


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County gray	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 14	Township number T 26 S	Range number R 28 <b>W</b>
2. Distance and direction from nearest town or city: of Cimarron Bridge Street address of well location if in city:	1 1/2 miles south		3. Owner of well: Herb Hoge R.R. or street: Comatton, Ks 67835 City, state, zip code:		
4. Locate with "X" in section below:  			Sketch map:		
			6. Bore hole dia. <u>20</u> in. Completion date <u>5-20-76</u> Well depth <u>180</u> ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <u>Steel</u> Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <u>36.87</u> lbs./ft. Dia. <u>16</u> in. to <u>18</u> in. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
5. Type and color of material			From	To	10. Screen: Manufacturer's name <u>Johnson Division</u> Type <u>Galv.</u> Dia. <u>16"</u> Slot/gauze <u>100</u> Length <u>20</u> Set between <u>150</u> ft. and <u>170</u> ft. Perf. <u>10-150</u> ft. and <u>170-180</u> ft. Gravel pack? <u>YES</u> Size range of material <u>15</u> in. Down
					11. Static water level: <u>9</u> ft. below land surface Date <u>1-1-76</u>
					12. Pumping level below land surfaces: <u>70</u> ft. after <u>3</u> hrs. pumping <u>1560</u> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <u>1550</u> g.p.m.
					13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date
					14. Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> inches above grade
					15. Well grouted? <u>YES</u> With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <u>0</u> ft. to <u>10</u> ft.
					16. Nearest source of possible contamination: <u>N/A</u> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
					17. Pump: Manufacturer's name <u>Goulds Us Pumps</u> Model number <u>12 jmc</u> HP <u>100</u> Volts <input type="checkbox"/> Length of drop pipe <u>120</u> ft. capacity <u>1000</u> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley
					19. Remarks:  <i>Drilling done by Central Syllabub Pratt, Kansas</i>
					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name <u>Box A</u> License No. Address <u>Garden City, Ks</u> Signed <u>Mike Minter</u> Date <u>7-16-76</u> Authorized representative

*Professional* **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

HERB HOGE  
Gray County  
12-24-75

Location: SE NE 14-26-28  
525 feet East of Test # 1

Static Water Level - 9'

Test # 2

0	3	Top Soil
3	43	Fine to Med. Sand & Gravel (Loose)
43	51	Brown Sandy Clay
51	65	Fine to Med. Sand & Gravel, Streaks of Clay (25%)
65	79	Fine to Med. Sand & Fine Gravel, Streaks of Clay (10%)
79	121	Fine to Med. Sand & Fine Gravel (Loose)
121	140	Fine to Med. Sand & Fine Gravel, Streaks of Clay (10%) (Tight)
140	177	Fine to Med. Sand & Gravel (Loose) Coarse Gravel
177	180	Brown & Yellow Clay
180	185	Shale