


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name Cimarron	Fraction Pivot SW $\frac{1}{4}$	Section number 15	Town number T 26 S	Range number R 28 W
Distance and direction from nearest town or city: <b>Across river at Cimarron, Ks., 1 west, 3/4 south 1/4 west</b>			3 Owner of well: <b>Charles Grasser</b> Address: <b>Cimarron, Ks. 67835</b>			
Locate with "X" in section below: 			Sketch map:		4 Well depth: <u>227</u> ft. Date of completion <u>5-8-75</u> Well diameter <u>26</u> in.	
					5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
					6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well	
					7 Casing: Material <b>Steel</b> Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>228</u> ft. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u>16</u> in. to <u>228</u> ft. depth	
					8 Screen: Manufacturer <b>Johnson Division</b> Type <b>Galv.</b> Dia. <u>16"</u> Slot/ <u>100</u> Length <u>20'</u> Set between <u>190</u> ft. and <u>210</u> ft. Perf: <b>70-190, 210-227</b> Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>1/2" down</u>	
					9 Static water level: <u>43</u> ft. below land surface Date <u>5-7-75</u>	
					10 Pumping level below land surfaces: <u>56</u> ft. after <u>2</u> hrs. pumping <u>925</u> g.p.m. <u>63</u> ft. after <u>4</u> hrs. pumping <u>1200</u> g.p.m. Estimated maximum yield <u>1200</u> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____	
					12 Well head completion: <input type="checkbox"/> Pitless adapter <u>12</u> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From <u>0</u> ft. to <u>10</u> ft.	
					14 Nearest source of possible contamination: <b>N/A</b> ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					15 Pump: <input type="checkbox"/> Not installed Manufacturer's name <b>Peerless-FMC</b> Model number <b>3861</b> HP <b>100</b> Volts _____ Length of drop pipe <u>180</u> ft. capacity <u>800</u> g.m.p. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)			16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			
17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Minter-Wilson Drilling Co. 208</b> Business name <b>Box 493 Garden City, Ks.</b> License No. _____ Address _____ Signature <b>Minter-Wilson Drilling Co. 208</b> Date <u>5-20-75</u> Authorized representative _____						

*The Professionals* **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Gray County

Chas. Grasser

March 10, 1975

Sec 15 T. 26 S. 28 Static Water Level 20

Location: Across River at Cima con, 1 mile west 3/4 mile South  
1/4 mile west on Pivot.

This test is 150' North of Test By Casterline or  
Shinstock in 1971.?

0	6	Fine to Medium Sand
6	26	Medium to Coarse Gravel
26	31	Brown Clay
31	46	Fine to Medium Sand & Gravel (Loose)
46	67	Brown Clay
67	80	Fine to Medium Sand & Gravel (Loose)
80	92	Brown Clay
92	116	Fine to Medium Sand & Gravel 10% Clay (Loose)
116	125	Brown Clay
125	140	Fine to Medium Sand & Gravel 20% Clay (Loose)
140	156	Fine to Medium Sand & Fine Gravel 10% Clay (Loose)
156	170	Brown Sandy Clay
170	187	Fine to Medium Sand & Gravel (Loose)
187	218	Fine to Medium Sand & Gravel with Brown Rock (Loose)
218	227	Fine to Medium Sand & Gravel with Brown Rock 10% Clay (Small Hard Streak)
227	235	Shale

TD 227