


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County GRAY	Township name	Fraction <del>SW</del> <del>SE</del> NW	Section number 15	Town number 26	Range number 28 W X
Distance and direction from nearest town or street address of well location if in city: 400 Yds. South of Cimarron Bridge 1 West, 1/2 South 3/4 West				3 Owner of well: Charles Grasser Cimarron, Ks. 67825 Address:		
Locate with "X" in section below: N  S 1 Mile				Sketch map:		
2				4 Well depth: 26 ft. Date of completion 11-5-75 Well diameter 170 in.		
Type and color of material				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Steel Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 171 ft. depth Drive shoe? <input type="checkbox"/> Yes <input type="checkbox"/> No Weight 36.8 lb./ft. 16 in. to ft. depth		
				8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot/gauze Length 20' Set between 145-165 ft. Fittings: Perf. 55-145 145-150 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 2" Down D		
				9 Static water level: ft. below land surface Date		
				10 Pumping level below land surfaces: 82 ft. after 3 hrs. pumping 1254 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1250 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 ft <input type="checkbox"/> Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite 10 Depth: From ft. to ft. N/A		
				14 Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: Manufacturer's name GouldsUS Pumps Model number K-2196HP 100 Volts Length of drop pipe 140 ft. capacity 1250 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation  Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Business name Address P.O.B. A Garden City, Ks. Signature Date 6-30-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

*The  
Professionals*

**MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

T J Gormaner  
Gray county  
NW 15-26-28  
10-11-75

Location: From south west corner go 1/10 ~~mi~~ of test #3  
TEST 4

0	2	Top soil
2	9	Fine sand
9	14	Brown sandy clay
14	21	Fine to med sand & gravel loose
21	37	Brown clay
37	43	Fine to med sand gravel clay streak
43	55	Brown sandy clay
55	70	Fine to med sand & gravel
70	80	Fine to med sand & gravel 10% clay
80	92	Fine to med sand & gravel loose
92	96	Brown sandy clay layer of gravel loose
96	100	Brown sandy clay
100	106	Fine to med sand
106	110	Fine to med sand & gravel loose
110	128	Fine to med sand & gravel clay streaks little tight
128	143	Brown sandy clay
143	155	Med sand & gravel loose good
155	165	Med sand & gravel mixed with some rock
165	172	Yellow mixed with rock hard hard
172	175	Shale

TD 170