

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction NW 1/4 SE 1/4 NW 1/4	Section number 16	Township number T 26 S	Range number R 28 E
2. Distance and direction from nearest town or city: 1 S & 2 W of Cimarron, KS Street address of well location if in city:			3. Owner of well: Wiley McFarland R.R. or street: Rural Route City, state, zip code: Cimarron, KS			
4. Locate with "X" in section below: N W E S 1 Mile 1 Mile		Sketch map: 		6. Bore hole dia. 17 1/2 in. Completion date 10-23-75 Well depth 185 ft.		
5. Type and color of material		From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
See Attachment				8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material Steel Height Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.7 lbs./ft. Dia. 123/4185 ft. depth 185 ft. Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 188		
				10. Screen: Manufacturer's name L. B. Foster Co. Type Slotted Dia. 12-3/4" Slot/gauze 1/8" Length 70" Set between 185 ft. and 165 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4"		
				11. Static water level Not Pumped mo./day/yr. ft. below land surface Date <input type="checkbox"/>		
				12. Pumping level below land surfaces: Not Test Pumped ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/> mo./day/yr.		
				14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
				15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
				16. Nearest source of possible contamination: Septic ft. 230 Direction NW Type Tank Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
				17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation: Flat Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle DRIG & Supply 145 Business name Box 639, Garden City, KS License No. <input type="checkbox"/> Address E. L. Bothwell Date 11-12-75 Signed E. L. Bothwell Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Wiley McFarland DATE 10-15-75
 STREET ADDRESS _____ TEST # Housewell
 CITY & STATE Cimarron, Kansas DRILLER Lee
 COUNTY Gray QUARTER NW SECTION 16 TOWNSHIP 26 RANGE 28

LOCATION South side of house

%	DRILLED FOOTAGE			Description of Strata	Static Water Level _____
	From	Pay	To		Proposed Well Depth <u>185</u>
	0		8	Basement	
	8		32	Drilled a little rough, had sand in sample	
	32		45	Brown clay	
	45		98	Brown clay, very few fine sand st, few ledges	
	98		104	Sand	
	104		130	Clay, few ledges, drilled slow	
	130		155	Clay, drilled slow, hard. Hard to tell what was	
				drilling.	
	155		185	Drilled like rock, some sand & some clay	

GARDEN CITY, KANSAS HENKLE DRILLING & SUPPLY CO., INC. SUBLETTE, KANSAS
 PHONE 276-3278 IRRIGATION HEADQUARTERS PHONE 675-4311
 TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****