


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Gray	SE 1/4 NW 1/4 SE 1/4	17	25 26	S R 28 NW
2. Distance and direction from nearest town or city:	South side of the Cimmaron Bridge 2 1/2 west 3/4 south 1/4 west		3. Owner of well:	Charles Thomas	
Street address of well location if in city:			R.R. or street:	Cimmaron, Ks. 67835	
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia.	20 in. Completion date 4-4-76	
			Well depth	204 ft.	
5. Type and color of material	From	To	7. Cable tool	Rotary Driven Dug Hollow rod Jetted Bored <input checked="" type="checkbox"/> Reverse rotary	
			8. Use:	Domestic Public supply Industry <input checked="" type="checkbox"/> Irrigation Air conditioning Stock Lawn Oil field water Other	
			9. Casing: Material	Steel Height: Above or below Threaded Welded <input checked="" type="checkbox"/> Surface 12 in. RMP PVC Weight 36.87 lbs./ft. Dia. 16 in. to 205 ft. depth Wall thickness: inches or Dia. 16 in. to ft. depth gage No. 250	
			10. Screen: Manufacturer's name	Johnson Division Type Gav. Dia. 16" Slot/gauze 100 Length 20' Set between 180 ft. and 200 ft. Perc. 80-180 ft. and 200-204 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/2" Down	
			11. Static water level:	mo./day/yr. 11 ft. below land surface Date 4-4-76	
			12. Pumping level below land surfaces:	76 ft. after 3 hrs. pumping 1500 p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
			13. Water sample submitted:	mo./day/yr. Yes <input checked="" type="checkbox"/> No Date	
			14. Well head completion:	12 Pitless adapter Inches above grade	
			15. Well grouted?	yes With: Neat cement Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
			16. Nearest source of possible contamination:	N/A ft. Direction Type <input checked="" type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No	
			17. Pump:	Not installed Manufacturer's name Goulds US Pump Model number 1211 HP 75 Volts Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: Submersible <input checked="" type="checkbox"/> Jet <input checked="" type="checkbox"/> Centrifugal <input checked="" type="checkbox"/> Turbine <input checked="" type="checkbox"/> Reciprocating <input checked="" type="checkbox"/> Other <input checked="" type="checkbox"/>	
18. Elevation:	19. Remarks:	Drilling done by Central Well & pump Pratt, Ks.			
Topography:	<input checked="" type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley				
	Business name <u>Minter Wilson Drilling 208</u> Address <u>P.O. Box A Garden City, KS.</u> Signature <u>Minter Wilson 8-3-76</u> Date <u>8-3-76</u> Authorized representative <u>Minter Wilson</u>				

The Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Comp. and Re.

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
2-25-76

LOCATION: SE 17-26-28

South, Cimarron Bridge, make Right Turn,
2½ Miles West, 3/4 Of Mile South, ½ Mile
West, 40 Feet East Of Pivot #17

STATIC WATER LEVEL: 60'

TEST #1

0	1	Top Soil
1	16	Fine Sand
16	22	Brown Sandy Clay
22	35	Coarse Gravel
35	49	Brown Sandy Clay
49	57	Fine To Med. Sand & Gravel
57	71	Brown Sandy Clay
71	75	Fine To Med. Sand
75	78	Brown Sandy Clay
78	121	Fine To Med. Sand & Gravel (Loose)
121	149	Brown Sandy Clay Sticky
149	155	Fine Sand
155	170	Fine To Med. Sand
170	185	Fine To Med. Sand & Gravel (Loose)
185	204	Med. Sand & Gravel Mixed With Coarse Yellow Brown Rock (Loose)
204	210	Yellow Clay
210	212	Shale
		80' Plain
		100' Perf
		20' Screen
		<u>4' Perf.</u>
	204	