

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

**WATER WELL RECORD**  
**KSA 82a-1201-1215**

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

*The Professionals* **MINTER-WILSON DRILLING CO.**  
INCORPORATED

Commercial  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS  
GRAY COUNTY  
2-26-76

LOCATION: SW 17-26-28  
½ Mile West To Pivot 17, Pivot 18 40  
Feet East Of Pivot

STATIC WATER LEVEL: 60'

TEST #2

0	1	Top Soil
1	10	Fine Sand
10	18	Brown Sandy Clay
18	51	Med. To Coarse Gravel (Loose)
51	58	Brown Sandy Clay
58	67	Med. Sand & Gravel (Loose)
67	84	Brown Sandy Clay
84	95	Fine To Med. Sand, Some Gravel (Loose)
95	136	Fine To Med. Sand & Gravel (Loose)
136	139	Brown Sandy Clay
139	145	Fine To Med. Sand
145	158	Brown Sandy Clay
158	170	Fine To Med. Sand & Gravel, Little Clay Streak
170	175	Fine To Med. Sand (tight)
175	190	Fine To Med. Sand (Loose)
190	197	Med. To Coarse Gravel Mixed Brown & Yellow Rock
197	200	Med. To Coarse Gravel with Brown, Yellow Rock & Clay Layer
200	204	Med. To Coarse Gravel with Brown & Yellow Rock (Loose)
204	209	Med. Coarse Gravel Mixed Brown & Yellow, Little tight
209	216	Brown, Yellow clay, Some Sandstone TracK

*The*  
*Professionals* **MINTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS  
GRAY COUNTY  
2-26-76  
-Cont-

218 225 Yellow And Shale

85' Plain  
100' Perf.  
20' Screen  
4' Perf.

209