


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NE 1/4 SW 1/4 NE 1/4	Section number 17	Township number T 26 S R 28	Range number NW	
2. Distance and direction from nearest town or city: bridge 3 1/4 west 3 1/4 north Street address of well location if in city:	Owner of well: Charles Thomas R.R. or street: Cimarron, Ks. 67835 City, state, zip code:					
4. Locate with "X" in section below: Sketch map: N  S 1 Mile	6. Bore hole dia. 26 in. Completion date 14-31-76 Well depth 205 ft.					
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <input type="checkbox"/> Steel <input type="checkbox"/> Copper <input type="checkbox"/> Aluminum Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 206 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			
			10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division Type <input type="checkbox"/> Galv. Dia. 16" <input type="checkbox"/> Slot/gauze <input type="checkbox"/> 100 Length 20' <input type="checkbox"/> Set between <input type="checkbox"/> 170 ft. and <input type="checkbox"/> 190 ft. Perf. <input type="checkbox"/> 90-170 ft. and <input type="checkbox"/> 190-205 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material <input type="checkbox"/> 1" Down			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 25 ft. below land surface Date 1-2-76			
			12. Pumping level below land surfaces: 51 ft. after <input type="checkbox"/> 3 hrs. pumping 1500 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> 1500 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No Date <input type="checkbox"/>			
			14. Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade <input checked="" type="checkbox"/> yes			
			15. Well grouted? <input type="checkbox"/> With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From <input type="checkbox"/> 0 ft. to <input type="checkbox"/> 10 ft.			
			16. Nearest source of possible contamination: <input type="checkbox"/> N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: <input type="checkbox"/> Goulds <input checked="" type="checkbox"/> Not Pictured Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> 12" HP <input type="checkbox"/> 125 Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> 160 ft. capacity <input type="checkbox"/> 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business Name <input type="checkbox"/> Box A Garden City, Ks. <input type="checkbox"/> Address <input type="checkbox"/> Signed <input type="checkbox"/> Isene Wilson Date 8-3-76 Authorized representative <input type="checkbox"/>
18. Elevation:	19. Remarks: Drilling done by Central Well & Pump Pratt, Ks.					
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

*The
Professionals*

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
3-1-76

LOCATION: NE $\frac{1}{4}$ 17-26-28
 $\frac{1}{2}$ Mile East Of Pivot 24 - 40 Feet East
Of Pivot 23

STATIC WATER LEVEL: 60'

TEST #8

0	1	Top Soil
1	6	Fine Sand
6	19	Coarse Gravel (Loose)
19	50	Brown Sandy Clay
50	88	Fine To Med. Sand & Gravel
88	92	Brown Sandy Clay
92	112	Fine To Med. Sand (10%) Gravel (Good, Loose)
112	134	Brown Sandy Clay
134	155	Fine To Med. Sand & Gravel (10%) Clay
155	187	Med. To Coarse Gravel Mixed With Brown, Yellow Rock (Loose)
187	205	Med. To Coarse Gravel Mixed With Brown, Yellow Rock (Little Tight)
205	207	Yellow Clay
207	210	Shale