

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NW 1/4 SW 1/4 NW 1/4	Section number 18	Township number T 26 S	Range number R 28 E/W	
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/4 miles south of the Cimarron Bridge 4 3/4 west 3/4 north Cimarron, Ks. 67835					
3. Owner of well: R. or street: City, state, zip code:						
4. Locate with "X" in section below: Sketch map:						
5. Type and color of material	From	To	6. Bore hole dia. 26 in. Completion date 1-31-76 Well depth 221 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <input type="checkbox"/> Steel <input checked="" type="checkbox"/> Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 225 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250 10. Screens: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 185-195 ft. and 205-215 ft. Perf. 100-185 ft. and 195-205, 215-225 ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 1/2" Diam 11. Static water level: mo./day/yr. 16 ft. below land surface Date 3-26-76 12. Pumping level below land surfaces: 83 ft. after 3 hrs. pumping 1475 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1475 g.p.m. 13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date 14. Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade 15. Well grouted? <input checked="" type="checkbox"/> YES With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No 17. Pump: Not installed Manufacturer's name Goulds US Pumps Model number 12" HP 125 Volts Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley 19. Remarks: Drilling Done By Central Well & Pump Pratt. Ks 20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name 90. Box A Garden City, Ks. Address Signed <i>John Minter</i> Date 8-3-76 Authorized representative			

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professionals **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
2-27-76

LOCATION: NW 18-
½ Mile North Of Pivot 20 - Pivot 26 40
Feet East Of Pivot #5

STATIC WATER LEVEL 60'

TEST #5

0	1	Top Soil
1	32	Fine Sand
32	76	Coarse Gravel
76	108	Brown Sandy Clay
108	125	Fine To Med. Sand & Gravel (Good-Loose)
125	144	Fine To Med. Sand, Some Gravel (Loose)
144	158	Brown Sandy Clay
158	166	Fine To Med. Sand & Gravel
166	176	Brown, Grey Clay
176	183	Med. Sand & Gravel, Some Rock
183	196	Med. To Coarse Gravel, Mixed Brown, Yellow Rock (Loose)
196	203	Brown Sandy Clay
203	224	Med. To Coarse Gravel Mixed With White Yellow Rock (Tight)
224	230	Yellow Shale

T.D. 224

Sub. 224