


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction SW 1/4 NE 1/4 SW 1/4	Section number 18	Township number T 26 S	Range number R 28 E/W	
2. Distance and direction from nearest town or city: Cimarron bridge	1 1/4 south of the Cimarron bridge 1 3/4 west 1/4 north					
Street address of well location if in city:		3. Owner of well: Charles Thomas R.R. or street: Cimarron, Ks. 67835 City, state, zip code:				
4. Locate with "X" in section below:		Sketch map: N 				
5. Type and color of material		From	To	6. Bore hole dia. 26 in. Completion date 4-31-76 Well depth 263 ft.		
				7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
				9. Casing: Material <input type="checkbox"/> steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 264 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
				10. Screen: Manufacturer's name Johnson Division Type <input type="checkbox"/> Galv. Dia. 16" Slot/gauze 100 Length 20' Set between 210-220 ft. and 250-260 ft. Perf. 100-210 ft. and 220-250-260 163 Gravel pack? <input type="checkbox"/> yes Size range of material 1" down		
				11. Static water level: <input type="checkbox"/> mo./day/yr. 69 ft. below land surface Date 1-3-76		
				12. Pumping level below land surfaces: 97 ft. after 3 hrs. pumping 11450 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 11450 g.p.m.		
				13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date		
				14. Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade		
				15. Well grouted? <input type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. N/A		
				16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Goulds US Pumps Model number 12" HP 75 Volts Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
		(Use a second sheet if needed)				
18. Elevation:	19. Remarks: Drilling done by Central Well & Pump Pratt, Ks.					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business Name: Box A garden City, Ks. Address: <i>Minter Wilson Drilling</i> Signed <i>Minter Wilson Drilling</i> Date 8-3-76 Authorized representative

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
2-26-76

LOCATION: SW 18-
½ Mile West Of Pivot 19
Pivot 20 -40 Feet East Of Pivot

STATIC WATER LEVEL: 70'

TEST #4

0	1	Top Soil
1	42	Fine Sand
42	46	Brown Sandy Clay
46	84	Med. To Coarse Gravel (Loose)
84	90	Brown Sandy Clay
90	100	Fine To Med. Sand & Gravel
100	103	Gray Clay
103	140	Fine To Med. Sand & Gravel (Loose)
140	152	Med. Sand & Gravel, Some Coarse Gravel (Loose)
152	171	Fine To Med. Sand & Gravel
171	187	Brown Clay, Stick
187	200	Fine To Med. Sand
200	211	Brown Sandy Clay
211	228	Med. To Coarse Gravel mixed With Yellow Rock
228	249	Brown Sandy Clay
249	263	Med. To Coarse Gravel Mixed with Brown, Yellow Rock (Tight)
263	266	Yellow Clay (Hard) (Hard)
266	270	Shale

T.D. 20'
20' Screen