

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:		County Gray	Fraction SW 1/4 SW 1/4 NE 1/4	Section number #18	Township number T #26	Range number S R #28	X/W
2. Distance and direction from nearest town or city: 1 mile south, 3 miles west, 1/2 South and 1/2 west of Street address of well location if in city: Cimarron, Ks.				3. Owner of well: Wiley McFarland R.R. or street: City, state, zip code: Cimarron, Kansas 67835			
4. Locate with "X" in section below:		Sketch map:			6. Bore hole dia. 8 in. Completion date 4-12-76 Well depth 250 ft.		
		in a pasture - no buildings			7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary		
5. Type and color of material		From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Top soil & fine sand		0	15	9. Casing: Material RMP Height: Above or Below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input checked="" type="checkbox"/> PVC <input type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 250 ft. depth Wall Thickness 250 inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Page No. 250			
Fine sand		15	45	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot 3/32" 1/8" Length 20 ft. Set between 225 ft. and 245 ft. ft. and <input type="checkbox"/> ft. Gravel pack? yes Size range of material 1/4"			
Fine to coarse sand		45	60	11. Static water level: 48 ft. below land surface Date 4-12-76 mo./day/yr.			
Coarse sand		60	75	12. Pumping level below land surfaces: 47 ft. after 2 hrs. pumping 60 g.p.m. ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 100 g.p.m.			
Medium sand & clay layers		75	90	13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
Fine to medium sand		90	105	14. Well head completion: None <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
Medium sand & clay layers		105	120	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 15 ft.			
Medium sand & rock layers		120	135	16. Nearest source of possible contamination: None ft. Direction <input type="checkbox"/> Type <input type="checkbox"/>			
Clay		135	150	Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Clay & medium sand		150	165	17. Pump: Windmill <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Clay		165	180	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name License No. Address Box 174 Cimarron, Ks. Signed Larry L. Crick Date 5-13-76 Authorized representative			
Clay & medium sand		180	195				
Medium sand		195	210				
Coarse sand		210	225				
225 Coarse sand & clay		225	240				
Clay, coarse sand, clay & blue shale		240	250				
18. Elevation:		19. Remarks:		20. Water well contractor's certification:			
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		Stock well - no contamination to our knowledge.					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5