


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number	
	GRAY	NE 1/4 SW 1/4 NW 1/4	18	T 26 S	R 28 E/W	
2. Distance and direction from nearest town or city: bridge 1/4 west 3/4 north	1 1/4 south of Cimarron	Owner of well:	Charles Thomas			
Street address of well location if in city:		R.R. or street:	Cimarron, Ks. 67835			
4. Locate with "X" in section below:	Sketch map:			6. Bore hole dia. 26 in. Completion date 11-31-76 Well depth 220 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
5. Type and color of material	From	To	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <input checked="" type="checkbox"/> steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 26.87 lbs./ft. Dia. 16 in. to 22 ft. depth Wall Thickness: inches or Dia. 16 in. to 22 ft. depth gage No. 1250			
			10. Screen: Manufacturer's name <input checked="" type="checkbox"/> Johnson Division Type <input checked="" type="checkbox"/> Galv. Dia. 16"			
			Type <input checked="" type="checkbox"/> Galv. Dia. 16" Slot/gauze 100 Length 20 ft. Set between 190 ft. and 210 ft. Perf. 90-190 ft. and 220-220 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1/16" down			
			11. Static water level: mo./day/yr. 50 ft. below land surface Date 3-26-76			
			12. Pumping level below land surfaces: 1300 91 ft. after 3 hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 1300 g.p.m.			
			13. Water sample submitted: mo./day/yr. Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Date			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 10 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. Direction Type N/A Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No			
			17. Pump: Not installed Manufacturer's name <input checked="" type="checkbox"/> Goulds US Pumps Model number 1211 HP 125 Volts Length of drop pipe 160 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
18. Elevation:	19. Remarks: Drilling done by Central Well & Pump Pratt, Ks.			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter Wilson Drilling 208 Business name <input type="checkbox"/> P.O. Box A Garden City, Ks Address <input type="checkbox"/> 8-3-76 Signed <input type="checkbox"/> Date <input type="checkbox"/> 8-3-76 Authorized representative		
Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

*The
Professionals*

MINTER-WILSON DRILLING CO.
INCORPORATED

Production
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
2-28-76

LOCATION: NE 18-
½ Mile East Of Pivot 26 - Pivot 25,40
Feet East Of Pivot

STATIC WATER LEVEL: 60'

TEST #

0	1	Top Soil
1	28	Fine Sand
28	44	Med. To Coarse Gravel
44	47	Brown Sandy
47	63	Fine To Med. Sand
63	78	Brown Sandy Clay
78	101	Fine To Med. Sand & Gravel (Tight)
101	106	Brown Sandy Clay
106	110	Fine To Med. Sand & Gravel (loose)
110	119	Brown Sandy Clay, Sand Streak
119	160	Brown Sandy Clay
160	174	Fine To Med. Sand & Gravel
174	184	Brown Sandy Clay
184	212	Med. To Coarse Gravel, Mixed Brown, Yellow, Rock (Loose)
212	223	Med. To Coarse Gravel Mixed Brown, Yellow, Rock (Tight)
223	226	Yellow Clay
226	228	Shale

T.D. 60'