


USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. Of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name Cimarron	Fraction Pivot NE 1/4	Section number 20	Town number T 26 S	Range number R 28 W
Distance and direction from nearest town or city: Across river bridge at Cimarron, Ks., first road west to dead end, 1 1/4 south, 1/4 west				3 Owner of well: Louie Beery Address: Cimarron, Ks. 67835		
Locate with "X" in section below: 				Sketch map:		
2				4 Well depth: 246 ft. Date of completion 5-1-75 Well diameter 26 in.		
				5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
				6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well		
				7 Casing: Material Steel Height: above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. Diam. 16 in. to 247 ft. depth! Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No _____ in. to _____ ft. depth!		
				8 Screen: Manufacturer Johnson Division Type Galv. Dia. 16" Slot/gauze _____ Length 20' Set between 195 ft. and 205 ft. 220-230 Perforations: 100-195, 205-220, 230-246 Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 2" down		
				9 Static water level: 49 ft. below land surface Date 5-3-75		
				10 Pumping level below land surfaces: 75 ft. after 3 hrs. pumping 1280 g.p.m. _____ ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 1200 g.p.m.		
				11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date _____		
				12 Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
				13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> _____ Depth: From 0 ft. to 10 ft.		
				14 Nearest source of possible contamination: N/A ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
				15 Pump: <input type="checkbox"/> Not installed Manufacturer's name Peerless-FMC Model number 4667 HP 100 Volts _____ Length of drop pipe 140 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
16 Remarks: elevation Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley				17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name _____ License No. _____ Address Box 493 Garden City, Ks. Signed [Signature] Date 5-27-75 Authorized representative		

Forward the white, blue and pink copies to the Kansas State Dept. Of Health.

Form WWC-5

The Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Gray County Kindsvater By Darrell Faulk March 19, 1975

NE $\frac{1}{4}$ sec.20 T.26 R. 28 Static Water Level 60 Test # 1 Pivot

Location: Across River At Cimarron, take first Road West
to Dead End, 1 $\frac{1}{4}$ mile South, $\frac{1}{4}$ West.

0	6	Fine Sand
6	32	Brown Clay
32	82	Medium to Coarse Gravel (Loose)
82	93	Fine to Medium Sand & Gravel 10% Clay (Loose)
93	143	Fine to Medium Sand & Gravel (Loose)
143	155	Brown Clay, streaks of Gravel 30% (Loose)
155	176	Fine to Medium Sand & Fine Gravel 10% Clay (Loose)
176	192	Brown Sandy Clay
192	207	Fine to Medium Sand & Gravel (Loose)
207	220	Brown Sandy Clay
220	230	Fine to Medium Sand & Gravel with Brown Rock (Loose)
230	246	Fine to Medium Sand & Gravel with Brown Rock (Hard Streak)
246	255	Shale (Hard)