

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SW 1/4 SW 1/4 NW 1/4	Section number 21	Township number T 26	Range number S R 28	E 10	
2. Distance and direction from nearest town or city: and 1 1/2 miles south of Cimarron Street address of well location if in city:	3. Owner of well: Charles Eversole R.R. or street: Route #1 City, state, zip code: Cimarron, Kansas 67835						
4. Locate with "X" in section below:	Sketch map:			8. Bore hole dia. 8 in. Completion date _____ Well depth 245 ft. 5-4-77			
			7. Cable tool XX Rotary Driven Dug Hollow rod Jetted Bored Reverse rotary				
5. Type and color of material	From	To	8. Use: XX Domestic Public supply Industry Irrigation Air conditioning Stock Lawn Oil field water Other				
Brown sandy topsoil	0	15	9. Casing: Material RMP Height: Above or below Threaded Welded Surface 12 in. RMP XX PVC Weight lbs./ft. Dia. 5 in. to 245 ft. depth Wall thickness: inches or Dia. in. to ft. depth gage No. 256				
Clay & fine sand	15	30	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" ft. Slot, gauge 1/8" Length 220 ft. Set between 220 ft. and 240 ft. Gravel pack? yes Size range of material 1/4"				
Clay layers & medium gravel	30	45	11. Static water level: mo./day/yr. 90 ft. below land surface Date 5-4-77				
Loose large gravel	45	60	12. Pumping level below land surfaces: 105 ft. after 1 hrs. pumping 50 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 65 g.p.m.				
Large gravel	60	75	13. Water sample submitted: mo./day/yr. Yes XX No Date				
Medium gravel & clay layers	75	90	14. Well head completion: X Pitless adapter 12 inches above grade				
Clay & medium sand	90	105	15. Well grouted? yes With: XX Neat cement Bentonite Concrete Depth: From 6 ft. to 20 ft.				
Coarse sand	105	120	16. Nearest source of possible contamination: ft. 50 Direction east Type Barn Yard Well disinfected upon completion? XX Yes No				
Coarse sand	120	135	17. Pump: Not installed Manufacturer's name Demster (used) Model number 1 HP 1 Volts 230 Length of drop pipe 117 ft. capacity 12 g.p.m. Type: XX Submersible Turbine Jet Reciprocating Centrifugal Other				
Medium to coarse sand & clay	135	150	18. Elevation: 19. Remarks: Topography: XX Hill Slope Upland Valley Has excellent drainage to the East and to the West				
(Use a second sheet if needed)				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Joe's Well Service 179 Business name License No. Address Box 174 Cimarron, Ks. Signed Larry Crick Date 7-22-77 Authorized representative			