


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number
	Gray	NE 1/4 SW 1/4 NE 1/4	22	T 26 S	R 28 A/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 1/4 south of Cimarron river bridge, 1 west, 1/4 south		3. Owner of well: R.R. or street: City, state, zip code:	Bradley Koehn Cimarron, Ks. 67835	
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 26 in. Completion date 1-26-77 Well depth 256 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material steel Height: Above ground Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 257 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
			10. Screen: Manufacturer's name Johnson Type Galv. Dia. 16" Slot/ <sup>open</sup> <input type="checkbox"/> Length 20 ft. Set between 220 ft. and 240 ft. Perf: 90-220 ft. and 240-256 ft. Gravel pack? yes Size range of material 2" down		
			11. Static water level: mo./day/yr. 63 ft. below land surface Date 1-7-77		
			12. Pumping level below land surfaces: 84 ft. after 2 hrs. pumping 1200 g.p.m. 94 ft. after 4 hrs. pumping 1800 g.p.m. Estimated maximum yield 1800 g.p.m.		
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No		
			17. Pump: Not installed Manufacturer's name Goulds - US Pump Model number 12JHC HP 100 Volts <input type="checkbox"/> Length of drop pipe 160 ft. capacity 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
			18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley		
			19. Remarks: (Use a second sheet if needed)		
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> License No. <input type="checkbox"/> Address Box A Garden City, Ks. Signed <input type="checkbox"/> Authorized representative Date 5-13-77 1/4 NE SW 1/4 1/4 1/4		

Professionals

**HUNTER-WILSON DRILLING CO.**  
INCORPORATED

Irrigation  
and Domestic  
Water Systems  
Complete Installation  
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

BRADLEY KOLBE  
GRAY COUNTY  
11-23-76

Location: NE 22-26-28 south of Cimarron to Ready Mix Plant  
1 west, 1/4 miles south 110 Ft. from pivot  
Static Water Level- 60'

Test #1

0	1	Top soil
1	21	Fine sand
21	36	Brown clay
36	72	Fine to med. sand and gravel Loose
72	91	Fine sand
91	151	Fine to med. sand and gravel Loose
151	172	Fine to med. sand and gravel with coarse rock and brown clay 10%
172	243	Fine to med. sand and gravel with coarse rock Loose
243	255	Fine to med. sand and gravel with coarse rock white rock
255	260	Yellow clay and shale

T.D. 256