

WATER WELL RECORD

Form WWC-5

KSA 82a-1212

1 LOCATION OF WATER WELL		Fraction NW 1/4 NW 1/4 NE 1/4				Section Number 23		Township Number T 26 S		Range Number R 28 E/W	
--------------------------	--	----------------------------------	--	--	--	----------------------	--	---------------------------	--	--------------------------	--

Distance and direction from nearest town or city? 1 1/2 miles South & 1/2 mile West of Cimarron, Kansas Street address of well if located within city?

2 WATER WELL OWNER: Danny Corsbie

RR#, St. Address, Box #

Board of Agriculture, Division of Water Resources
Application Number:

City, State, ZIP Code: Cimarron, Kansas 67825

3 DEPTH OF COMPLETED WELL 225 ft. Bore Hole Diameter 8 in. to 225 ft. and in. to ft.

Well Water to be used as: 5 Public water supply 8 Air conditioning 11 Injection well

1 Domestic 3 Feedlot

6 Oil field water supply

12 Other (Specify below)

2 Irrigation 4 Industrial

7 Lawn and garden only

10 Observation well

Well's static water level 56 ft. below land surface measured on August month 2 day 1979 year

Pump Test Data: Well water was 56 ft. after 1 hour pumping. 50 gpm

Est. Yield 70 gpm: Well water was ft. after hours pumping gpm

4 TYPE OF BLANK CASING USED: 5 Wrought iron 8 Concrete tile Casing Joints: Glued XX Clamped

1 Steel 3 RMP (SR) 6 Asbestos-Cement 9 Other (specify below) Welded

2 PVC - Jet Stream 4 ABS 7 Fiberglass Threaded

Blank casing dia 5 in. to 225 ft., Dia in. to ft., Dia in. to ft.

Casing height above land surface 12 in., weight lbs./ft. Wall thickness or gauge No. 200

TYPE OF SCREEN OR PERFORATION MATERIAL: 7 PVC 10 Asbestos-cement

1 Steel 3 Stainless steel 5 Fiberglass 8 RMP (SR) 11 Other (specify)

2 Brass 4 Galvanized steel 6 Concrete tile 9 ABS 12 None used (open hole)

Screen or Perforation Openings Are: 5 Gauzed wrapped 8 Saw cut 11 None (open hole)

1 Continuous slot 3 Mill slot 6 Wire wrapped 9 Drilled holes

2 Louvered shutter 4 Key punched 7 Torch cut 10 Other (specify)

Screen-Perforation Dia 1/8 in. to 20 ft., Dia in. to ft., Dia in. to ft.

Screen-Perforated Intervals: From 200 ft. to 220 ft., From ft. to ft.

From ft. to ft., From ft. to ft.

Gravel Pack Intervals: From 20 ft. to 200 ft., From ft. to ft.

From ft. to ft., From ft. to ft.

5 GROUT MATERIAL: 1 Neat cement 2 Cement grout 3 Bentonite 4 Other

Grouted Intervals: From 10 ft. to 20 ft., From ft. to ft., From ft. to ft.

What is the nearest source of possible contamination: New building site 10 Fuel storage 14 Abandoned water well

1 Septic tank 4 Cess pool 7 Sewage lagoon 11 Fertilizer storage 15 Oil well/Gas well

2 Sewer lines 5 Seepage pit 8 Feed yard 12 Insecticide storage 16 Other (specify below)

3 Lateral lines 6 Pit privy 9 Livestock pens 13 Watertight sewer lines

Direction from well How many feet? Water Well Disinfected? Yes XX No

Was a chemical/bacteriological sample submitted to Department? Yes No XX If yes, date sample

was submitted month day year: Pump Installed? Yes XX No

If Yes: Pump Manufacturer's name Flint & Walling Model No. 10BK9 HP 1 Volts 230

Depth of Pump Intake 129 ft. Pumps Capacity rated at 19 gal/min.

Type of pump: 1 Submersible 2 Turbine 3 Jet 4 Centrifugal 5 Reciprocating 6 Other

6 CONTRACTOR'S OR LANDOWNER'S CERTIFICATION: This water well was (1) constructed, (2) reconstructed, or (3) plugged under my jurisdiction and was

completed on August month 9 day 1979 year

and this record is true to the best of my knowledge and belief. Kansas Water Well Contractor's License No. 179

This Water Well Record was completed on August month 22 day 1979 year under the business


name of JOHN'S WELL SERVICE by (signature) Larry Crick

7 LOCATE WELL'S LOCATION WITH AN "X" IN SECTION BOX:

FROM	TO	LITHOLOGIC LOG	FROM	TO	LITHOLOGIC LOG
0	15	Top soil & fine to coarse sand			
15	30	Coarse sand	195	210	Coarse sand & clay *4ft.
30	45	Coarse to medium sand	210	225	Coarse sand & rock layers
45	60	Medium sand & clay			
60	90	Fine sand & clay layers			
90	120	Clay layers to medium to coarse sand			
120	135	Clay layers & fine sand			
135	150	Fine sand			
150	165	Fine sand & clay layers			
165	180	Clay & medium sand			
180	195	Medium to coarse sand			

Depth(s) Groundwater Encountered 1 ft. 2 ft. 3 ft. 4 ft. (Use a second sheet if needed)

INSTRUCTIONS: Use typewriter or ball point pen, please press firmly and PRINT clearly. Please fill in blanks, underline or circle the correct answers. Send top three copies to Kansas Department of Health and Environment, Division of Environment, Water Well Contractors, Topeka, KS 66620. Send one to WATER WELL OWNER and retain one for your records.



ELEVATION:

Depth(s) Groundwater Encountered 1 ft. 2 ft. 3 ft. 4 ft. (Use a second sheet if needed)

OFFICE USE ONLY

SEC