

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

**WATER WELL RECORD**  
KSA 82g-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

CWW Inv. # 12653

1. Location of well:	County Gray	Fraction <b>C</b> 1/4 SW <sub>1/4</sub> SW <sub>1/4</sub>	Section number 23	Township number 26	Range number 28			
2. Distance and direction from nearest town or city Cimarron, $\frac{1}{4}$ west. Street address of well location if in city:	2 miles south of Cimarron		3. Owner of well: Bob Carlile R.R. or street: 1141 S. Pershing City, state, zip code: Liberal, Kansas 67901					
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 9 in. Completion date 9-4- Well depth 120 ft. 7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary 8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material <input type="checkbox"/> steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 28 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 24.63 lbs./ft. Dia. 10 in. to 35 ft. depth Wall Thickness: inches or Dia. 10 in. to 120 ft. depth gage No. 219 10. Screen: Manufacturer's name Doerr Type steel Dia. 10" 60 Slot/gauze .030 Length Set between 35 ft. and 75 ft. 95 ft. and 115 ft. Gravel pack? yes Size range of material 1/8 to 11. Static water level: 35 ft. below land surface Date 9-4-76 12. Pumping level below land surfaces: ft. after hrs. pumping g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield unknown g.p.m. 13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date 14. Well head completion: Pitless adapter 28 Inches above grade 15. Well grouted? yes With <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From ft. to 10 ft. 16. Nearest source of possible contamination: none ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No 17. Pump: Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley 19. Remarks: <p>(Use a second sheet if needed)</p>			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Carlile Water Well 118</b> Business name <b>Box 275, Liberal, KS</b> License No. Address Signed <b>Edward E. Means</b> Date <b>9-2</b> Authorized representative		