


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray Co.	Section NE 1/4 SE 1/4 NE 1/4	Section number 23	Township number T 26	Range number S R 28	E/W E/W
2. Distance and direction from nearest town or city: 1 South of Cimarron Bridge, 100' West, 20' South of road Street address of well location if in city:			3. Owner of well: Clarence Kerr R.R. or street: 301 S. 3rd City, state, zip code: Cimarron, KS 67835			
4. Locate with "X" in section below: 			Sketch map:			6. Bore hole dia. 26 in. Completion date 2-28-78 Well depth 227 ft.
5. Type and color of material			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 1 ft. in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 227 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219			
			Screen: Manufacturer's name No Screen Used Type <input checked="" type="checkbox"/> Slot/gauze <input checked="" type="checkbox"/> Length <input checked="" type="checkbox"/> Set between 0-95 Plain 95-227 Perf. ft. ft. and <input type="checkbox"/> ft. Gravel pack <input checked="" type="checkbox"/> Size range of material 1/4 to 5/8			
			11. Static water level: <input type="checkbox"/> mo./day/yr. 34 ft. below land surface Date 1-8-78			
			12. Pumping level below land surfaces: 69 ft. after 2 hrs. pumping 1400 g.p.m. 85 ft. after 4 hrs. pumping 2100 g.p.m. Estimated maximum yield 2100 g.p.m.			
			13. Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 1 ft. inches above grade			
			15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction N/A Type <input type="checkbox"/> <input checked="" type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
17. Pump: <input type="checkbox"/> Not installed Manufacturer's name Gould 3 stg. 10" Model number <input type="checkbox"/> HP 50 Volts <input type="checkbox"/> Length of drop pipe 100 ft. capacity 600 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other						
(Use a second sheet if needed)						
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley	19. Remarks:			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name Rox A. Garden City, KS 67846 License No. <input type="checkbox"/> Address Box A, Garden City, KS 67846 Signed M. Minter Date 2/1/79 Authorized representative		

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The
Professionals

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67846

CLARENCE KERR

GRAY COUNTY

7-18-77

Location: NE 23-26-28 1 mile south of Cimarron
Bridge 1000 ft. west 20 ft. south of road

Static Water Level- 40'

Test #1

0	3	Top soil
3	6	Fine sand
6	11	Fine to med. sand
11	16	Fine to med. sand and gravel Loose
16	53	Coarse gravel
53	58	Light brown sandy clay hard
58	72	Fine to med. sand and gravel
72	94	Brown sandy clay
94	157	Fine to med. sand and gravel
157	165	Brown sandy clay
165	181	Fine to med. sand and gravel
171	180	Fine to med. sand and gravel mixed with small yellow rock
180	216	Med. sand to med. coarse gravel mixed with yellow and white rock
216	223	Fine to med. sand and gravel mixed with small yellow and white rock tight
223	227	Yellow clay
227	230	Shale

T.D. 227