


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number	
	GRAY	SE/4 NW 1/4 SEd 1/4	26	T 26	S R 28 <i>SW</i>	
2. Distance and direction from nearest town or city: of Cimarron stop light Street address of well location if in city?	3 3/4 south 1/4 west		3. Owner of well: R.R. or street: City, state, zip code:	John Ratzlaff Rt. L Cimarron, Ks 67835		
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 26 in. Completion date 5-31-76 Well depth 210 ft.			
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <input checked="" type="checkbox"/> Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 211 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gage No. <input type="checkbox"/>			
			10. Screen: Manufacturer's name Johnson Division			
			Type Galv Dia. 16"! Slot/gauze 100 Length 20' Set between 184 ft. and 204 ft. Perf. 80-184 ft. and 201-210 ft. Gravel pack? <input checked="" type="checkbox"/> YES Size range of material 2" Down			
			11. Static water level: 52 ft. below land surface Date 4-21-76 mo./day/yr.			
			12. Pumping level below land surfaces: 69 ft. after 3 hrs. pumping 1500 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 1500 g.p.m.			
			13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date			
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> YES With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
			17. Pump: Not installed Manufacturer's name Peerless FMC Model number 125B HP 125 <i>1800</i> g.p.m. Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
			18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley			
			19. Remarks: Drilling done by Central Well and Pump Pratt, Ks (L. Honomichl) Used Casing			
			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winter Wilson Drilling 208 Business name P.O. Box A Garden City, Ks Address <i>McLean, Ks</i> Date 7-16-76 Signature <i>Winter Wilson</i> Authorized representative			

The Professionals • **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

JOHN OTZLAFF
CHAY COUNTY
3-11-76

LOCATION: SW 1/4 26-26-23

STATIC WATER LEVEL: 50'

TEST #

0	1	Top Soil
1	25	Fine Sand
25	34	Brown Sandy Clay
34	124	Coarse Gravel (Loose)
124	153	Fine To Bed. Sand & Gravel
153	168	Brown Sandy Clay
168	179	Fine To Bed. Sand
179	184	Brown Sandy Clay (Hard)
184	205	Bed. To Coarse Gravel Mixed Brown & Yellow Rock (Loose)
205	210	Yellow Clay, Mixed Rock (Hard) Full Down
210	213	Shale

TO 210

50'	Plain
104'	Perf.
205'	Screen
210'	Perf.

210'