

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction NE 1/4 SE 1/4 NE 1/4 SE 1/4	Section number 26	Township number T 26	Range number S R 28 E 0	
2. Distance and direction from nearest town or city: Highway 23 of Cimarron, Ks. Street address of well location if in city:	3 miles south on John Ratzliff R.R. or street: R. R. City, state, zip code: Cimarron, Kansas 67835					
4. Locate with "X" in section below: Sketch map:						
5. Type and color of material	From	To	6. Bore hole dia. 8 in. Completion date _____ Well depth 220 ft. 3-3-77			
Top soil & fine sand	0	15	7. <input checked="" type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input checked="" type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
Fine sand & clay	15	30	8. Use: <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
Clay	30	45	9. Casing: Material RMP Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP XX PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5 in. to 220 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. 250			
Clay & medium sand	45	60	10. Screen: Manufacturer's name Sunflower Type RMP Dia. 5" Slot XX 1/8" in Length 20 ft. Set between 200 ft. and 220 ft. ft. and _____ ft. Gravel pack? yes Size range of material 1"			
Coarse sand	60	120	11. Static water level: mo./day/yr. 75 ft. below land surface Date 3-3-77			
Coarse sand & clay	120	135	12. Pumping level below land surfaces: 80 ft. after 1 hrs. pumping 50 g.p.m. ft. after _____ hrs. pumping _____ g.p.m. Estimated maximum yield 75 g.p.m.			
Clay	135	150	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No <input type="checkbox"/> Date _____			
Clay & fine sand layers	150	180	14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter 12 inches above grade			
Clay & fine sand layers, coarse sand (2ft.)	180	195	15. Well grouted? yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 8 ft. to 20 ft.			
Coarse sand	195	215	16. Nearest source of possible contamination: Barn ft. 70 Direction West Type Yard Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Coarse sand, coarse clay & blue shale	215	225	17. Pump: XX Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						
18. Elevation:	19. Remarks: Has good drainage to the West.					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name _____ License No. _____ Address Box 174 Cimarron, Ks. Signed Tom L. Clegg Date _____ Authorized representative _____