


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well: County Gray	Fraction 258 south center 1/4 1/4 1/4	Section number 53	Township number T 26	Range number S R 28 E/W
2. Distance and direction from nearest town or city: 5 mi south, 2 1/4 west, 1/4 north Cimarron Street address of well location if in city:	3. Owner of well: Bill Byer R.R. or street: Cimarron, Kansas City, state, zip code:			
4. Locate with "X" in section below: Sketch map: N  W E S 1 Mile	6. Bore hole dia. 28 in. Completion date 7-6-76 Well depth 235 ft.			
	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary			
	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
	9. Casing: Material Metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 31.56 lbs./ft. Dia. 16 in. to 235 ft. depth Wall thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. 100			
	10. Screen: Manufacturer's name W.A. Brown Free-flo Type 10% 1/8 Dia. 16 Slot/gauze <input type="checkbox"/> Length <input type="checkbox"/> ft. Set between 75 ft. and 235 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 3/8 down			
	11. Static water level: 80 mo./day/yr. ft. below land surface Date 5-24-76			
	12. Pumping level below land surfaces: 100 ft. after 1 hrs. pumping 800 g.p.m. 115 ft. after 1 hrs. pumping 1200 g.p.m. Estimated maximum yield 1600 g.p.m.			
	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
	14. Well head completion: <input type="checkbox"/> Pitless adapter <input checked="" type="checkbox"/> Inches above grade			
	15. Well grouted? No With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <input type="checkbox"/> ft. to <input type="checkbox"/> ft.			
	16. Nearest source of possible contamination: ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No			
	17. Pump: Not installed Manufacturer's name Goulds Model number 12JMO HP 100 Volts Length of drop pipe 180 ft. capacity 900 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
	(Use a second sheet if needed)			
18. Elevation: Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks: 10' of grout and pump slab to be installed by the customer-he knows this is a regulation	20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Ace-Hi International 190 Business name <input type="checkbox"/> License No. Address Dodge City, Kansas Signed <i>Bill Byer</i> Authorized representative Date 7-26-76		