


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

2629 W 3 CW
T R EW sec 1/4 1/4 1/4 No.

Kansas State Dept. of Health
(Water Well Contractors)
Forbes-Bldg. 740
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name	Fraction Center of $\frac{1}{4}$	Section number 3	Town number T 26 S	Range number R 29 W
Distance and direction from nearest town or city: 1 $\frac{1}{2}$ west & $\frac{1}{2}$ south of Ingalls, KS			3 Owner of well: Clarence Irsik Address: Ingalls, KS			
Locate with "X" in section below: N			Sketch map: Well Drilled 9/22/75			4 Well depth: 192 ft. Date of completion 9/23/75 Well diameter 26 in.
						5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary
						6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well
						7 Casing: Material Steel Height: above/below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 2 in. Diam. 16 in. to 192 in. Weight lbs./ft. 16 in. to 192 in. Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No in. to ft. depth
2 Type and color of material See Attachment			From	To	8 Screen: Manufacturer Johnson Type Continuous Dia. 16" Slot/gauze .150 Length 20' Set between 190 ft. and 170 ft. Fittings: Gravel pack <input type="checkbox"/> Yes <input type="checkbox"/> No Size range of material 1/2"	
					9 Static water level: 34 ft. below land surface Date 9/23/75	
					10 Pumping level below land surfaces: 67 ft. after hrs. pumping 1323 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
					12 Well head completion: 12 <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Depth: From 0 ft. to 10 ft.	
					14 Nearest source of possible contamination: none ft. Direction Type Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name Model number HP Volts Length of drop pipe ft. capacity g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)					16 Remarks: elevation Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	
					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilling & Supply Business name Address Box 639 Garden City, KS Signature E.L. Bothwell Date 10-3-75 Authorized representative	

DRILLERS TEST LOG

Irrigation
Well

CUSTOMERS NAME Clarence Irsik DATE 8-22-75
 STREET ADDRESS TEST # 1 E-Log 220'
 CITY & STATE Ingalls, KS DRILLER Rector
 COUNTY Gray QUARTER NW SECTION 3 TOWNSHIP 26 RANGE 29

LOCATION In center of 1/4 & 18' N & W of Pivot Point

%	DRILLED FOOTAGE			Description of Strata	WELL LOCATION Static Water Level Proposed Well Depth
	From	Pay	To		
	0		10	Sand	
	10		25	Sand & Gravel	
	25		36	Brown clay	
	36		43	Sand fine to med coarse	
	43		65	Brown sandy clay & sand	
	65		70	Brown clay	
	70		75	Sand & gravel	
	75		80	Brown chalky clay	
45	80	10	90	Sand fine to med coarse, med small	
	90		105	Brown chalky clay	
35	105	15	120	Sand fine to med coarse & brown sandy clay	
65	120	11	131	Sand fine to med coarse, small gravel, real loose, used water	
	131		149	Brown chalky clay	
75	149	41	190	Sand fine to med coarse, small coarse, med to small gravel & small white & tan & brown rock loose, & ragged, used water.	
	190		193	Soapstone & clay (hard)	
	193		200	Hard blue shale	

TOTAL DEPTH OF WELL 192'

Can set up face west & pit on north
or Face south & pit on the west