


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:		County <b>Gray</b>	Fraction <b>SW 1/4 NW 1/4 NE 1/4</b>	Section number <b>3</b>	Township number <b>T 26 S R 29 E</b>	Range number <b>W</b>
2. Distance and direction from nearest town or city: <b>3/4 S. &amp; 3/4 W. of Ingalls</b> Street address of well location if in city:				3. Owner of well: <b>Clarence Irsik</b> R.R. or street: City, state, zip code: <b>Ingalls, KS 67853</b>		
4. Locate with "X" in section below:		Sketch map:		6. Bore hole dia. <b>26</b> in. Completion date <b>3/16/76</b> Well depth <b>175</b> ft.		
		<b>Well drilled 3-11-76</b>		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material		From		To		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other
See attachment						9. Casing: Material <b>Steel</b> Height <b>Above</b> or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <b>12</b> in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight <b>31</b> lbs./ft. Dia. <b>26</b> in. to <b>175</b> ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <b>188</b>
						10. Screen: Manufacturer's name <b>Johnson</b> Type <b>Continuous</b> Dia. <b>16"</b> Slot/gauze <b>100 &amp; 150</b> Length <b>40'</b> Set between <b>100</b> ft. and <b>120</b> ft. <b>150</b> ft. and <b>170</b> ft. Gravel pack? <b>Yes</b> Size range of material <b>1/4 - 1/8</b>
						11. Static water level: <input type="checkbox"/> mo./day/yr. <b>25</b> ft. below land surface Date <b>3/16/76</b>
						12. Pumping level below land surfaces: <b>80</b> ft. after <input type="checkbox"/> hrs. pumping <b>1800</b> g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
						13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>
						14. Well head completion: <input type="checkbox"/> Pitless adapter <b>12</b> inches above grade
						15. Well grouted? <b>Yes</b> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From <b>0</b> ft. to <b>10</b> ft.
						16. Nearest source of possible contamination: <b>None observed</b> ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
						17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
18. Elevation:		19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Supply 145</b> Business name License No. <input type="checkbox"/> Address <b>Box 639, Garden City, KS</b> Signed <b>J. W. Henkle</b> Date <b>3-7-76</b> Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input checked="" type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

## DRILLERS TEST LOG

CUSTOMERS NAME	Clarence Irsik	DATE	2-27-76
STREET ADDRESS		TEST #	1 E. Log 175 F
CITY & STATE	Ingalls, Kansas	DRILLER	Rector
COUNTY	Gray	QUARTER	NE SECTION 3 TOWNSHIP 26RANGE 29
LOCATION	660 Ft. South of NW corner of NE $\frac{1}{4}$ Right along West side of		

## WELL LOCATION

	DRILLED		FOOTAGE	STATIC WATER LEVEL
%	FROM	PAY	TO	PROPOSED WELL DEPTH
	0		5	Sand
	5		10	Clay
	10		28	Sand and gravel
	28		32	Brown clay
45	32	28	63	Sand fine med. coarse, small gravel. L Loose. Used water. Mud Heavy.
	63		75	Brown clay
55	75	5	80	Sand fine med. coarse, used water. Loose.
	80		97	Brown clay, sticky
60	97	19	116	Sand fine med. coarse, med. to small gravel. Real loose. Used water. Mud heavy.
	116		140	Brown clay, gyp rock and chalk
80	140	32	172	Sand fine med. coarse, med. to small prov gravel small white and tan rock. Real loose. Used lots of water. Mud heavy Very good.
	172		176	Brown clay and soapstone
	176		180	Shale, limey, hard.
		84		TOTAL DEPTH OF WELL 175'
				Set up facing North Pit on the East or Set up facing West Pit on the North Whichever is best.

HENKLE DRILLING & SUPPLY CO., INC.

GARDEN CITY, KANSAS

Phone 276-3278

SUBLETTE, KANSAS

Phone 675-4311

## TEST HOLES

## DOMESTIC WELLS

STOCK WELLS

## IRRIGATION & INDUSTRIAL WELLS