


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction Center of 1/4 1/4 NE 1/4	Section number 4	Township number T 26 S R 29 E/W	Range number
2. Distance and direction from nearest town or city: 2 1/4 W. & 1/4 S. of Ingalls Street address of well location if in city:			3. Owner of well: Diane Janof R.R. or street: C/O Sidney Warner City, state, zip code: Cimarron, KS 67835		
4. Locate with "X" in section below: Sketch map: 			6. Bore hole dia. 26 in. Completion date 9-17-76 Well depth 210 ft.		
5. Type and color of material See attachment			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36 lbs./ft. Dia. 16 in. to 210 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250		
			10. Screen: Manufacturer's name Johnson Type Continuous Dia. 16" Slot/gauze 100 Length 30' Set between 195 ft. and 165 ft. ft. and <input type="checkbox"/> ft. Gravel pack? Yes Size range of material 1/4 x 1/8		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 39 ft. below land surface Date 9-20-76		
			12. Pumping level below land surfaces: 85 ft. after <input type="checkbox"/> hrs. pumping 1435 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <input type="checkbox"/>		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 Inches above grade		
			15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: None observed ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <input type="checkbox"/> Model number <input type="checkbox"/> HP <input type="checkbox"/> Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> ft. capacity <input type="checkbox"/> g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other					
(Use a second sheet if needed)					
18. Elevation: Hill Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drlg. & Supply 145 Business name License No. Address Box 639 Garden City, KS Signed E.L. Bohrer Date 10-4-76 Authorized representative		

26
29
4
1/4
1/4
1/4

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

DRILLERS TEST LOG

CUSTOMERS NAME Diane Janof DATE 9-1-76
 STREET ADDRESS c/o Sidney Warner TEST # 1 E. Log 220'
 CITY & STATE Cimarron, KS DRILLER Rector
 COUNTY Gray QUARTER NE SECTION 4 TOWNSHIP 26 RANGE 29

LOCATION Center of 1/4 and 18' W. of Pivot

%	DRILLED FOOTAGE		Description of Strata	WELL LOCATION	
	From	Pay To		Static Water Level	Proposed Well Depth
	0	8	Sand		
	8	18	Sand and gravel		
	18	22	Brown clay		
	22	25	Sand		
	25	55	Brown clay and sand sts.		
45	55	72	Sand fine med. coarse and small gravel, used lots of water, mud heavy		
	72	84	Brown clay and caliche		
55	84	99	Sand fine med. coarse, few small gravel, loose, used water, mud heavy, ledge at 85 ft.		
	99	120	Brown clay, small sand sts. and caliche		
55	120	136	Sand fine med. coarse, med. small gravel and fine sandy clay mixed (loose) used lots of water		
	136	160	Brown clay, firm		
65	160	167	Sand fine med. coarse, med. small gravel		
75	167	201	Sand fine med. coarse, med. to small gravel, tan rock, brown rock and white rock, drilled firm, used water		
	201	204	Soapstone (hard)		
	204	220	Shale (hard)		
	104				
			TOTAL DEPTH OF WELL 210 FT.		
			Set up south		
			Pit on west		

GARDEN CITY, KANSAS
 PHONE 276-3278

HENKLE DRILLING & SUPPLY CO., INC.
 IRRIGATION HEADQUARTERS

SUBLETTE, KANSAS
 PHONE 675-4311

TEST HOLES*****STOCK WELLS*****IRRIGATION AND INDUSTRIAL WELLS*****