


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE 1/4 SW 1/4 NE 1/4	Section number 4	Township number T 26	Range number S R 29	E/W
2. Distance and direction from nearest town or city: 8 W. & 3/4 N. of Cimarron Street address of well location if in city:	3. Owner of well: Diane Janof R.R. or street: C/o Sid Warner Cimarron, KS 67835					
4. Locate with "X" in section below: Sketch map: N  1 Mile W E S 1 Mile	6. Bore hole dia. 10 5/8 in. Completion date 8-4-76 Well depth 215 ft.					
5. Type and color of material See attachment	From	To	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary			
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
			9. Casing: Material <input checked="" type="checkbox"/> Plastic Height: Above or below Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight _____ lbs./ft. Dia. 5/8 in. to 215 ft. depth Wall Thickness: inches or Dia. _____ in. to _____ ft. depth Gage No. .316			
			10. Screen: Manufacturer's name <input checked="" type="checkbox"/> Jet Stream			
			Type Slotted Dia. 6 5/8" Slot/gauze .040 Length 30' Set between 215 ft. and 185 ft. ft. and _____ ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 8-12			
			11. Static water level: Not pumped mo./day/yr. ft. below land surface Date			
			12. Pumping level below land surfaces: Not pumped ft. after _____ hrs. pumping g.p.m. ft. after _____ hrs. pumping g.p.m. Estimated maximum yield g.p.m.			
			13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date			
			14. Well head completion: <input checked="" type="checkbox"/> Pitless adapter _____ inches above grade			
			15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.			
			16. Nearest source of possible contamination: None ft. _____ Direction _____ Type _____ Well disinfected upon completion? <input checked="" type="checkbox"/> Yes _____ No			
			17. Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name _____ Model number _____ HP _____ Volts _____ Length of drop pipe _____ ft. capacity _____ g.p.m. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)						
18. Elevation: Flat	19. Remarks:					
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						
20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Henkle Drilg. & Supply 145 Business name <input type="checkbox"/> License No. Address <input type="checkbox"/> Box 639 Garden City, KS Signed <input type="checkbox"/> Date 8-23 Authorized representative						

DRILLERS TEST LOG

CUSTOMERS NAME Diane Janof c/o Sid Warner DATE 8-3-76
 STREET ADDRESS TEST # 1 Stock Well
 CITY & STATE Cimarron, KS DRILLER Lee E. Log
 COUNTY Gray QUARTER NE SECTION 4 TOWNSHIP 26 RANGE 29

LOCATION Approx. 15 ft. E. of present well

WELL LOCATION

%	DRILLED FOOTAGE			Description of Strata	Static Water Level Proposed Well Depth
	From	Pay	To		
	0		4	Top soil, sandy	
	4		16	Brown clay	
	16		32	Sand fine med. coarse, small med. to large gravel, very few clay st., used water	
	32		70	Brown clay, few hard ledges, used pull down some	
	70		100	Brown clay, few ledges, few sand st.	
	100		160	Brown and tan clay, a little sticky, very few ledges or sand st.	
	160		184	Brown clay, few ledges, broken gyp rock, very few sand st.	
65	184	30	214	Sand fine med. coarse, small gravel, few med., brown gravel, white and tan rock few clay st., ledges in places, drilled a little tight in places	
	214		216	Soapstone ledges	
	215		220	Shale, very hard	

TOTAL DEPTH OF WELL 215'

6 5/8" plastic casing

2 T. 8-12 special gravel pack

5 1/2 sacks of Revert, special drilling mud for large
gravel

0-215' Reamed out test to 10 5/8". Set heavy duty
plastic casing with cap on bottom.

215'-185' Perforation

185'- 0 Plain