


USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

21629 W 1/4 CSE  
T R EW sec 1/4 1/4 1/4 No.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas State Dept. of Health  
(Water Well Contractors)  
Forbes-Bldg. 740  
Topeka, Kansas 66620

1 Location of well:	County Gray	Township name	Fraction Center of <u>1</u>	Section number <u>4</u>	Town number T 26 S	Range number R 29 W
Distance and direction from nearest town or city: 3 miles W & $\frac{1}{2}$ S of Ingalls, KS			3 Owner of well: Diane Janof c/o Sidney Warner Cimarron, KS			
Street address of well location if in city:						
Locate with "X" in section below:  			Sketch map:  Well Drilled 9/19/75			
			4 Well depth: <u>215</u> ft. Date of completion <u>9/23/75</u> Well diameter <u>26</u> in. 5 <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 6 Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Commercial <input type="checkbox"/> Test well			
			7 Casing: Material <u>Steel</u> Height: <u>above</u> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface <u>12</u> in. Diam. <u>16</u> in. to <u>215</u> in. Weight <u>16</u> lbs./ft. 16 in. to <u>215</u> in. depth Drive shoe? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <u> </u> in. to <u> </u> ft. depth			
2 Type and color of material			From	To	8 Screen: Manufacturer <u>Johnson</u> Type <u>Continuous</u> Dia. <u>16"</u> Slot/gauze <u>150</u> Length <u>30'</u> Set between <u>210</u> ft. and <u>180</u> ft. Fittings: Gravel pack <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No Size range of material <u>12"</u>	
See Attachment					9 Static water level: <u>44</u> ft. below land surface Date <u>9/23/75</u>	
					10 Pumping level below land surfaces: <u>97</u> ft. after <u> </u> hrs. pumping <u>1435</u> g.p.m. <u> </u> ft. after <u> </u> hrs. pumping <u> </u> g.p.m. Estimated maximum yield <u> </u> g.p.m.	
					11 Water sample submitted: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date <u> </u>	
					12 Well head completion: <u>12</u> <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade	
					13 Well grouted? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> <u> </u> Depth: From <u>0</u> ft. to <u>10</u> ft.	
					14 Nearest source of possible contamination: <u>none</u> ft. <u> </u> Direction <u> </u> Type <u>observed</u> Well disinfected upon completion? <input type="checkbox"/> Yes <input type="checkbox"/> No	
					15 Pump: <input checked="" type="checkbox"/> Not installed Manufacturer's name <u> </u> Model number <u> </u> HP <u> </u> Volts <u> </u> Length of drop pipe <u> </u> ft. capacity <u> </u> g.m.p. Type: <input type="checkbox"/> Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(use a second sheet if needed)					17 Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. <b>Henkle Drilling &amp; Supply</b> 1450 Business name <u> </u> License No. <u> </u> Address <u>Box 639 Garden City</u> Signed <u>E. L. Bethwell</u> Date <u>10-3-75</u> Authorized representative	
16 Remarks: elevation  Topography: <input checked="" type="checkbox"/> Hill <input type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley						

Forward the white, blue and pink copies to the Kansas State Dept. of Health.

Form WWC-5

## DRILLERS TEST LOG

CUSTOMERS NAME Diane Janof DATE 8-5-75  
 STREET ADDRESS • Sidney Warner TEST 1  
 CITY & STATE Simarron, Kansas DRILLER Lee  
 COUNTY Gray QUARTER SE SECTION 4 TOWNSHIP 26 RANGE 29

LOCATION 20 Ft. North of Pivot in Center of Quarter

%	DRILLED FOOTAGE FROM PAY TO			DESCRIPTION OF STRATA	Static Water Level Proposed Well Depth	WELL LOCATION
	0		2	Sand		
	2		5	Clay		
	5		9	Sand fine, medium		
	9		12	Brown clay		
	12		30	Sand fine med. coarse, small, med to some large gravel. Loose Used water.		
	30		39	Brown clay		
	39		53	Sand fine med. coarse, few, small gravel, very few clay st. Loose.		
	53		62	Brown clay, ledges, few broken rock. Few sand st.		
	62		79	Sand fine med. coarse, few small gravel.		
	79		108	Brown clay, broken white rock. Sand streaks. Fine to med. Few limerock ledges.		
	108		128	Brown clay, limerock ledges, used pulldown some. Few white rock Very few sand st.		
50	128	18	146	Sand fine med. some coarse, few, small gravel. Few clay st. Loose in places. Used some water.		
	146		174	Brown clay, broken rock, few ledges Very few sand st.		
35	174	6	180	Sand fine med. some coarse, very few clay st.		
70	180	20	200	Sand fine med. coarse, small to med. gravel. Few white and tan rock a lot of brown gravel.		
75	200	7	207	Sand fine med. coarse, small to med. gravel. White and tan rock and a lot of brown gravel.		
65	207	6	213	Some sand coarse, white and tan rock. Few brown gravel. Few ledges.		
213			216	Brown clay, hard ledges, very hard at 215'		
216			220	Shale, very hard.		
			57			
TOTAL DEPTH OF WELL 215'						
Set rig up West. Pit on the north.						