

USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE 1/4 SW1/4 SW/4	Section number 7	Township number T 26	Range number S R 29 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	3 South, 1 E, 1 S. of Charleston, Ks.		3. Owner of well: Lyle Davis R.R. or street: 210 North 3rd City, state, zip code: Cimarron, Kansas		
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 28 in. Completion date 2-28-77 Well depth 198 ft.		
	924' E of the SW corner of the SW ^{1/4} , Sec. 7, T26S, R29W, Gray County, Kansas.		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
Fine sand	0	20	9. Casing: Material <input checked="" type="checkbox"/> St1 Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 37 lbs./ft. Dia. 16 in. to 96 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 219		
Fine sand, clay streaks	20	64	10. Screen: Manufacturer's name Foster, Cook Type W/W Millslot dia. 16" Slot/gauze 1/8" Length 102' Set between 96 ft. and 198 ft. ft. and ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 4.7 mm		
Fine to coarse sand	64	96	11. Static water level: mo./day/yr. 86 ft. below land surface Date 1-12-77		
Fine to coarse sand, medium gravel	96	162	12. Pumping level below land surfaces: 92 ft. after 1/2 hrs. pumping 1040 g.p.m. 102 ft. after 1 hrs. pumping 2844 g.p.m. Estimated maximum yield 3500 g.p.m.		
Fine to coarse sand, large gravel	162	196	13. Water sample submitted: mo./day/yr. Yes <input checked="" type="checkbox"/> No Date		
Tan clay	196	256	14. Well head completion: Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Fine to coarse sand (hard)	256	266	15. Well grouted? <input checked="" type="checkbox"/> With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Tan sandy clay (hard)	266	292	16. Nearest source of possible contamination: unk ft. Direction Type Well disinfected upon completion? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Black shale	292	300	17. Pump: Not installed Manufacturer's name Layne & Bowler Model number 12KM HP Volts Length of drop pipe 180 ft. capacity 800 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Layne-Western Co., Inc. 100 Business name <input type="checkbox"/> Address Garden City, Ks. Signed <input type="checkbox"/> Authorized representative <input type="checkbox"/> Date May 77		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					