


USE PENCIL OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County: Gray	Fraction: NW 1/4 SE 1/4 NW 1/4	Section number: 9	Township number: T 26	Range number: S 29 E/W
2. Distance and direction from nearest town or city: <input checked="" type="checkbox"/> South of Charleston, Ks. to Plymell Jct., 3/4 east, Street address of well location if in city: 1/4 south	3. Owner of well: Fred Rowan R.R. or street: Ingalls, Ks. 67853				
4. Locate with "X" in section below:	Sketch map: 	6. Bore hole dia. 26 in. Completion date 9-6-75 Well depth 235 ft.			
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material <input checked="" type="checkbox"/> steel Height: Above or <input type="checkbox"/> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 236 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 219 MUC		
			10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Division Type <input checked="" type="checkbox"/> Galv. Dia. 16" Slot/ <input type="checkbox"/> Length 20' Set between 160-170 ft. and 220-230 ft. Pert: 80-160 m 170-220, 230-235 ft. Gravel pack? <input type="checkbox"/> yes Size range of material 1/2" down		
			11. Static water level: <input type="checkbox"/> mo./day/yr. 54 ft. below land surface Date 9-8-75		
			12. Pumping level below land surfaces: 87 ft. after 2 hrs. pumping 812 g.p.m. 98 ft. after 4 hrs. pumping 1324 g.p.m. Estimated maximum yield 1300 g.p.m.		
			13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date		
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		
			15. Well grouted? <input type="checkbox"/> Yes With: <input checked="" type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
			16. Nearest source of possible contamination: <input type="checkbox"/> N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
			17. Pump: Manufacturer's name <input type="checkbox"/> Peerless - FMC Model number 5296 HP 100 Volts Length of drop pipe 140 ft. capacity 1300 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> Box 493 Garden City, Ks. Address <input type="checkbox"/> 11-22 Date <input type="checkbox"/> Signed <input type="checkbox"/> by <input type="checkbox"/> Date <input type="checkbox"/> Authorized representative <input type="checkbox"/>		
18. Elevation:	19. Remarks:				
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

MINTER-WILSON DRILLING CO.

INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

Fred Rowan
Sept. 19, 74

Test # 1

Location: North West $\frac{1}{4}$ Sec. 9, T. 26, R. 29
1 Mile South of Ingalls river bridge
1 $\frac{3}{4}$ Miles West, $\frac{1}{4}$ Mile South

0	20	Top Soil & sand clay
20	35	Fine sand
35	55	Fine to med. sand & gravel (Loose)
55	80	Sandy clay
80	105	Fine to med. sand & gravel (Loose)
105	128	Sandy clay streaks of sand & gravel (Loose)
128	135	Fine to med. sand & gravel (2%) clay
135	155	Clay
155	175	Fine to med. sand & gravel (Loose)
175	200	Sandy clay
200	210	Med. sand
210	235	Fine to med. sand & gravel (Loose)
235	240	Shale

Drilled this one
Total Depth: 235'

20' Screen