


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction SE $\frac{1}{4}$ NW $\frac{1}{4}$ SE $\frac{1}{4}$	Section number 11	Township number T 26	Range number S 29	E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	1 $\frac{1}{2}$ south, 3/4 east, $\frac{1}{4}$ north of Ingalls.		3. Owner of well: R.R. or street: City, state, zip code:	Jack Wartman Pierceville, Ks. 67868		
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 26 in. Completion date 5-18-77 Well depth 236 ft.		7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	
5. Type and color of material	From	To	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		9. Casing: Material <input checked="" type="checkbox"/> steel Height: Above <input type="checkbox"/> below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 237 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. 250	
			10. Screen: Manufacturer's name <input type="checkbox"/> Johnson Type <input checked="" type="checkbox"/> galv. Dia. 16"		11. Static water level: <input type="checkbox"/> mo./day/yr. 53 ft. below land surface Date 4-9-77	
			12. Pumping level below land surfaces: 74 ft. after 2 hrs. pumping 1100 g.p.m. 84 ft. after 4 hrs. pumping 1700 g.p.m. Estimated maximum yield 1700 g.p.m.		13. Water sample submitted: <input type="checkbox"/> mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date	
			14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade		15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.	
			16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		17. Pump: Not installed Manufacturer's name <input type="checkbox"/> Goulds - US Pump Model number <input type="checkbox"/> 12JMO HP <input type="checkbox"/> 75 Volts <input type="checkbox"/> Length of drop pipe <input type="checkbox"/> 140 ft. capacity <input type="checkbox"/> 1200 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other	
(Use a second sheet if needed)					18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley	
			19. Remarks:		20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling Co. 208 Business name <input type="checkbox"/> Address <input type="checkbox"/> Box A Garden City, Ks. Signed <input type="checkbox"/> Date 7-25 Authorized representative <input type="checkbox"/> Form WWC-5	

Professionals' MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box A • GARDEN CITY, KANSAS 67847

JACK WARTMAN
GRAY COUNTY
3/9/77

Location: SE 11-26-29 250 Ft. south of pivot
Static Water Level- 45'

Test #3

0	12	Fine sand
12	21	Brown clay
21	51	Fine to med. sand and gravel
51	62	Brown clay
62	84	Fine to med. sand and gravel
84	93	Brown clay
93	117	Fine to med. sand and gravel
117	184	Brown clay
184	229	Fine to med. sand and gravel
229	236	Brown and yellow clay
236	245	shale

T.D. 236