


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

Well #3

1. Location of well:	County	Fraction	Section number	Township number	Range number		
	Gray	SW 1/4 NW 1/4 NE 1/4	#12	T #26	S R #29	E N	
2. Distance and direction from nearest town or city: 1 mile south, $5\frac{1}{2}$ miles west and $\frac{1}{2}$ north of Cimarron, Ks.	3. Owner of well: Wiley McFarland						
Street address of well location if in city:	R.R. or street:						
4. Locate with "X" in section below:		Sketch map:	6. Bore hole dia. 8 in. Completion date 11-16-76 Well depth 195 ft.				
		in a pasture - no buildings	7. <input type="checkbox"/> Cable tool <input checked="" type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input type="checkbox"/> Reverse rotary				
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input checked="" type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other				
			9. Casing: Material PVC Height: Above or Stock Threaded <input type="checkbox"/> Welded <input type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input checked="" type="checkbox"/> Weight <input type="checkbox"/> lbs./ft. Dia. 5 in. to 195 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth Gauge No. Sch. 40				
5. Type and color of material		From	To	10. Screen: Manufacturer's name ASTM Type PVC Dia. 5" Slot/size 1/8" Length 20 ft. Set between 170 ft. and 190 ft. ft. and 180 ft. Gravel pack? yes Size range of material 1"			
		0	15	11. Static water level: 15 ft. below land surface Date 11-16-76			
Top soil & coarse sand		15	30	12. Pumping level below land surfaces: 15 ft. after 2 hrs. pumping 80 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield 130 g.p.m.			
Coarse sand (very loose)		30	45	13. Water sample submitted: mo./day/yr. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No Date 11-16-76			
Coarse sand & clay		45	60	14. Well head completion: None <input type="checkbox"/> Pitless adapter <input type="checkbox"/> Inches above grade			
Clay		60	135	15. Well grouted? yes With: <input type="checkbox"/> Neat cement <input checked="" type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 30 ft.			
Clay & fine sand layers		135	150	16. Nearest source of possible contamination: ft. 1000 Direction North Type River Well disinfected upon completion? X Yes No			
Fine sand		150	165	17. Pump: Windmill <input checked="" type="checkbox"/> Not installed Manufacturer's name None Model number None HP None Volts None Length of drop pipe None ft. capacity None g.p.m. Type: Submersible <input type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
Fine to medium sand		165	180				
Medium to coarse (loose) sand		180	195				
Medium to coarse clay layers		195	210				
Medium to coarse sand & rock							
(Use a second sheet if needed)							
18. Elevation:	19. Remarks:					20. Water well contractor's certification:	
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley	could be contaminated by the river if it flooded.					This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. JOE'S WELL SERVICE 179 Business name None License No. None Address Box 174 Cimarron, Ks. Signed Larry L. Clegg Date 5-13-79 Authorized representative	