

USE TYPEWRITER OR BALL
POINT PEN—PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction SE $\frac{1}{4}$ NW $\frac{1}{4}$ SW $\frac{1}{4}$	Section number 12	Township number T 26 S R 29 $\frac{1}{4}$ W	Range number 29 $\frac{1}{4}$ W
2. Distance and direction from nearest town or city: Cimmaron bridge 5 $\frac{1}{2}$ west 1 $\frac{1}{2}$ north Street address or well location if in city:	3. Owner of well: Charles Thomas R.R. or street: Cimmaron, Ks. 67835 City, state, zip code:				
4. Locate with "X" in section below:	Sketch map: 				6. Bore hole dia. 26 in. Completion date 7-28-66 Well depth 224 ft.
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
		8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other			
		9. Casing: Material <input type="checkbox"/> steel <input checked="" type="checkbox"/> iron Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 225 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>			
		10. Screen: Manufacturer's name Johnson Division Type Galv. Dia. 16" Slot/gauze 100 Length 201 Set between 190 ft. and 210 ft. 90-190 ft. and 210-224 ft. Gravel pack? <input checked="" type="checkbox"/> Yes Size range of material 1-11 Down			
		11. Static water level: 140 ft. below land surface Date 1-7-76			
		12. Pumping level below land surfaces: 71 ft. after 3 hrs. pumping 1525 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 750 g.p.m.			
		13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date			
		14. Well head completion: Pitless adapter 12 inches above grade			
		15. Well grouted? <input checked="" type="checkbox"/> Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. N/A			
		16. Nearest source of possible contamination: ft. Direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/> No			
		17. Pump: Not installed Manufacturer's name Goulds U.S. Pumps Model number 724 HP 125 Volts Length of drop pipe 140 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other			
(Use a second sheet if needed)					
18. Elevation:	19. Remarks: Drilling done by Central Well & Pump Pratt, Ks.				20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Winton Wilson Drilling 208 Business name <input type="checkbox"/> License No. Address P.O. Box A Garden City, Ks. Signed <i>Winton Wilson</i> Date 8-12-76 Authorized representative
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

Form WWC-5

The Professional **MINTER-WILSON DRILLING CO.** INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
3-4-76

LOCATION: SE 12-26-29
South Of Cimarron Bridge, Turn Right, Go
2½ Mi. West, 1 Mile South, 2 Miles West,
1½ North To Pivot

STATIC WATER LEVEL: 60'

TEST #14	Pivot 30
0	1 Top Soil
1	22 Fine Sand
22	37 Med. To Coarse Gravel
37	46 Brown Sand Clay Clay
46	65 Fine To Med. Sand & Gravel (Loose)
65	83 Brown Sandy Clay
83	92 Fine To Med. Sand & Gravel
92	105 Brown Sandy Clay
105	128 Fine To Med. Sand & Gravel
128	152 Brown Sandy Clay
152	168 Fine To Med. Sand
168	171 Brown Sandy Clay
171	208 Med. To Coarse Gravel Mixed With Brown, Yellow, Rock (Loose)
208	224 Med. To Coarse Gravel Mixed With Brown, Yellow Rock (Little Tight)
224	227 Yellow Clay
227	228 Shale
TD	224
	90' Plain
	100' Perf.
	20' Screen
	14' <u>Perf.</u>
	<u>224'</u>