


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction SW 1/4 NE 1/4 NW 1/4	Section number	Township number	Range number
Gray			13	T 26	S R 29 SW
2. Distance and direction from nearest town or city: South of Cimarron bridge, 1 1/2 miles, 5 3/4 West, 3/4 North			3. Owner of well: Charles Thomas R.R. or street: City, state, zip code: Cimarron, KS 67835		
4. Locate with "X" in section below: 			Sketch map:		
			6. Bore hole dia. 26 in. Completion date 7-28-76 Well depth 200 ft.		
			7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary		
			8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material Steel Height: Above 200 ft. Threaded <input type="checkbox"/> Welded XX Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 201 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/>		
5. Type and color of material			From	To	10. Screen: Manufacturer's name Johnson
					Type Galvanized Dia. 16" Slot/ 100 Length 201 Set between 170 ft. and 190 ft. Perf: 80-170 ft. and 190-200 ft. Gravel pack? Yes Size range of material 1/2" down
					11. Static water level: 44 ft. below land surface Date 3-26-76
					12. Pumping level below land surfaces: 76 ft. after 3 hrs. pumping 1550 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> g.p.m.
					13. Water sample submitted: Yes XX No Date <input type="checkbox"/>
					14. Well head completion: <input type="checkbox"/> Pitless adapter 12 inches above grade
					15. Well grouted? Yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite XX Concrete Depth: From 0 ft. to 10 ft.
					16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes XX No <input type="checkbox"/>
					17. Pump: Manufacturer's name Goulds- US Pump Model number 12" HP 75 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity 1000 g.p.m. Type: <input type="checkbox"/> Submersible X Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other
(Use a second sheet if needed)					18. Elevation:
					19. Remarks: Drilling done by Central Well & Pump Pratt, KS Customer furnished 75 HP Electric Motor & Panel S/N ELJ514504
Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. Minter-Wilson Drilling 208 Business name <input type="checkbox"/> License No. Address Box A, Garden City, KS Signed M. Minter Date 8-12-76 Authorized representative <input type="checkbox"/>

*The
Professionals*

MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

CHARLES THOMAS
GRAY COUNTY
3-3-76

LOCATION: NW^{1/4} 13-26-29
70 Feet East Of Pivot - Pivot 28

STATIC WATER LEVEL: 70'

TEST #12

0	1	Top Soil
1	39	Fine Sand
39	50	Brown Sandy Clay
50	80	Fine To Med. Sand & Gravel
80	87	Brown Sandy Clay
87	97	Fine To Med. Sand & Gravel (10%) Clay
97	107	Fine To Med. Sand & Gravel (Loose)
107	112	Light Brown Sandy Clay
112	131	Fine To Med. Sand & Gravel
131	162	Brown Sandy Clay
162	176	Fine To Med. Sand & Gravel
176	196	Brown Sandy Clay
196	200	Fine To Med. Sand & Gravel
200	208	Brown Sandy Clay
208	233	Med. To Coarse Gravel Mixed With Brown & Yellow Rock (Loose)
233	258	Brown Sandy Clay Pull Down
258	261	Yellow
261	266	Shale