

USE TYPEWRITER OR BALL
POINT PEN-FPRESS FIRMLY,
PRINT CLEARLY.

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County	Fraction	Section number	Township number	Range number	
	Gray	NW 1/4 SE 1/4 NW 1/4	20	T 26	S R 29 FW	
2. Distance and direction from nearest town or city:	3 south of		3. Owner of well:	Don Renick		
Street address of well location if in city:	Ingalls, 2 3/4 west.		R.R. or street:			
4. Locate with "X" in section below:	Sketch map:		6. Bore hole dia.	26	in. Completion date 5-31-75	
			Well depth	228	ft.	
5. Type and color of material	From	To	7. Use:	<input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			8. Use:	<input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other		
			9. Casing: Material	steel	Height: Above <input type="checkbox"/> Surface <input checked="" type="checkbox"/> 12 in.	
			RMP	PVC	Weight 36.87 lbs./ft.	
			Dia. 16 in.	to 229 ft. depth	Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth <input type="checkbox"/> gage No. 250	
			10. Screen: Manufacturer's name	Johnson		
			Type	galv.	Dia. 16"	
			Slot/gauge	Length 20 ft.		
			Set between	175	ft. and 195 ft.	
			Perf: 80-175	ft. and 195-228	ft.	
			Gravel pack?	yes	Size range of material 1/2" down	
			11. Static water level:	65 ft. below land surface Date 5-12-75		
			12. Pumping level below land surfaces:			
			ft. after	hrs. pumping	g.p.m.	
			82	3	1170	
			Estimated maximum yield	1170 g.p.m.		
			13. Water sample submitted:	mo./day/yr.		
			Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	Date		
			14. Well head completion:			
			Pitless adapter	12 Inches above grade		
			15. Well grouted?	yes		
			With:	Neat cement	Bentonite <input checked="" type="checkbox"/> Concrete	
			Depth: From	0 ft.	to 10 ft.	
			16. Nearest source of possible contamination:	N/A		
			ft.	Direction	Type	
			Well disinfected upon completion?	Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		
			17. Pump:	Not installed		
			Manufacturer's name	Peerless - FMC		
			Model number	HP 100	Volts	
			Length of drop pipe	140 ft.	capacity 1150 g.p.m.	
			Type:			
			<input type="checkbox"/> Submersible	<input checked="" type="checkbox"/> Turbine		
			<input type="checkbox"/> Jet	<input type="checkbox"/> Reciprocating		
			<input type="checkbox"/> Centrifugal	<input type="checkbox"/> Other		
18. Elevation:	19. Remarks: (Use a second sheet if needed)					20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief. 208 Minter-Wilson Drilling Co., Inc. Business name <input type="checkbox"/> License No. Address Box A Garden City, Ks. Signed <i>John Minter</i> Date 9-30-75 Authorized representative
Topography:						
<input type="checkbox"/> Hill						
<input checked="" type="checkbox"/> Slope						
<input type="checkbox"/> Upland						
<input type="checkbox"/> Valley						

WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON RENICK
Gray County
4-10-75

Location: NW $\frac{1}{4}$ 20-26-29 South of Charleston to Plymell Rd.
2 miles East, 2 $\frac{1}{4}$ South, $\frac{1}{4}$ East

Test # 1 Pivot

6	6	Fine sand
6	37	Brown clay
37	84	Med. to coarse gravel
84	107	Fine to med. sand & gravel (Loose)
107	125	Brown clay (Tight)
125	131	Fine to med. sand & gravel 10% clay (Loose)
131	140	Brown clay & white rock (Tight)
140	159	Brown clay & white rock-streaks of gravel 35%
159	177	Brown clay
177	196	Fine to med. sand & gravel (Loose) w/brown rock
196	204	Brown clay
204	220	Brown gray & yellow clay w/white rock (Hard)
220	230	Shale (Hard)