

USE TYPEWRITER OR BALL  
POINT PEN-PRESS FIRMLY,  
PRINT CLEARLY.

WATER WELL RECORD  
KSA 82a-1201-1215

Kansas Department of Health and  
Environment-Division of Environment  
(Water well Contractors)  
Topeka, Kansas 66620

1. Location of well:	County Gray	Fraction Near center SE $\frac{1}{4}$ 1/4 1/4 1/4	Section number 23	Township number T 26 S	Range number R 29 E/W
2. Distance and direction from nearest town or city: Street address of well location if in city:	3-3/4 mi. south of Ingalls		3. Owner of well: R.R. or street: City, state, zip code:	Richard Batman Ingalls, Kansas	
4. Locate with "X" in section below:	Sketch map: 		6. Bore hole dia. 20 in. Completion date _____ Well depth 231 ft. 6-1-78		
5. Type and color of material	From	To	7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary	8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other	
Surface	0	3	9. Casing: Material metal Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 231 ft. depth Wall Thickness: inches or Dia. in. to ft. depth gage No. 219		
Sandy clay and sand	3	55	10. Screen: Manufacturer's name W. A. Brown		
Fine to coarse sand and gravel	55	150	Type 10% Free-flo Dia. 16 Slot/gauze 1/8 Length 180 Set between 51 ft. and 231 ft. ft. and $\frac{1}{2}$ ft. Gravel pack? yes Size range of material $\frac{1}{2}$ down		
Extra good med. to coarse sand and gravel	150	182	11. Static water level: 80 ft. below land surface Date 5-31-78		
Yellow clay	182	195	12. Pumping level below land surfaces: 105 ft. after 4 hrs. pumping 1800 g.p.m. ft. after hrs. pumping g.p.m. Estimated maximum yield 3000 g.p.m.		
50% fine sand-50% clay	195	205	13. Water sample submitted: Yes <input checked="" type="checkbox"/> No Date		
Good med. to coarse sand and gravel	205	231	14. Well head completion: Pitless adapter <input checked="" type="checkbox"/> Inches above grade		
Fine sand	231	240	15. Well grouted? yes		
Clay with 40% fine sand	240	250	With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input checked="" type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft.		
Sandy yellow clay	250	275	16. Nearest source of possible contamination: field ft. direction Type Well disinfected upon completion? Yes <input checked="" type="checkbox"/>		
Blue shale	275	285	17. Pump: Manufacturer's name Goulds Model number 12JMO HP 100 Volts 900 Length of drop pipe 160 ft. capacity g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other		
(Use a second sheet if needed)			20. Water well contractor's certification: This well was drilled under my jurisdiction and this report is true to the best of my knowledge and belief.		
18. Elevation:	19. Remarks:		Business name Ace-Hi International License No. 190 Address Dodge City, Kansas Signed Carl G. Smith Date 6-16 Authorized representative		
Topography: <input type="checkbox"/> Hill <input type="checkbox"/> Slope <input checked="" type="checkbox"/> Upland <input type="checkbox"/> Valley					

Forward the white, blue and pink copies to the Department of Health and Environment

**Form WWC-5**