


USE TYPEWRITER OR BALL
POINT PEN-PRESS FIRMLY,
PRINT CLEARLY. ~

WATER WELL RECORD
KSA 82a-1201-1215

Kansas Department of Health and
Environment-Division of Environment
(Water well Contractors)
Topeka, Kansas 66620

1. Location of well:	County GRAY	Fraction NE SW 1/4 SW 1/4	Section number 23	Township number T 26 S	Range number R 29 SW					
2. Distance and direction from nearest town or city: South $\frac{1}{2}$ East of Ingalls Street address of well location if in city:	3. Owner of well: Arthur Wells R.R. or street: 6774 Capatrana Way City, state, zip code: Riverside, Calif. 92500									
4. Locate with "X" in section below: Sketch map: N  W E S 1 Mile	6. Bore hole dia. 26 in. Completion date 4-30-76 Well depth 216 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 217 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/> 10. Screen: Manufacturer's name Johnson Division Type Galvane <input type="checkbox"/> Dia. 16 1/2 in. Slot/gauze 100 <input type="checkbox"/> Length 20 ft. Set between 160-170 ft. and 190-200 ft. Perf. 110-160 ft. and 170-190-200 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 2 1/2 in. down 11. Static water level: 64 ft. below land surface Date 4-26-76 mo./day/yr. 12. Pumping level below land surfaces: 71 ft. after 3 hrs. pumping 1350 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> 1350 g.p.m. 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date 14. Well head completion: 12 Pitless adapter <input type="checkbox"/> Inches above grade 15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 17. Pump: Not installed Manufacturer's name Peerless FMC Model number 121B HP 100 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity <input type="checkbox"/> 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley 19. Remarks: Drilling done by Central Well and Pump (Honomichl)					6. Bore hole dia. 26 in. Completion date 4-30-76 Well depth 216 ft. 7. <input type="checkbox"/> Cable tool <input type="checkbox"/> Rotary <input type="checkbox"/> Driven <input type="checkbox"/> Dug <input type="checkbox"/> Hollow rod <input type="checkbox"/> Jetted <input type="checkbox"/> Bored <input checked="" type="checkbox"/> Reverse rotary 8. Use: <input type="checkbox"/> Domestic <input type="checkbox"/> Public supply <input type="checkbox"/> Industry <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Air conditioning <input type="checkbox"/> Stock <input type="checkbox"/> Lawn <input type="checkbox"/> Oil field water <input type="checkbox"/> Other 9. Casing: Material Steel Height: Above or below Threaded <input type="checkbox"/> Welded <input checked="" type="checkbox"/> Surface 12 in. RMP <input type="checkbox"/> PVC <input type="checkbox"/> Weight 36.87 lbs./ft. Dia. 16 in. to 217 ft. depth Wall Thickness: inches or Dia. <input type="checkbox"/> in. to <input type="checkbox"/> ft. depth gage No. <input type="checkbox"/> 10. Screen: Manufacturer's name Johnson Division Type Galvane <input type="checkbox"/> Dia. 16 1/2 in. Slot/gauze 100 <input type="checkbox"/> Length 20 ft. Set between 160-170 ft. and 190-200 ft. Perf. 110-160 ft. and 170-190-200 ft. Gravel pack? <input checked="" type="checkbox"/> Size range of material 2 1/2 in. down 11. Static water level: 64 ft. below land surface Date 4-26-76 mo./day/yr. 12. Pumping level below land surfaces: 71 ft. after 3 hrs. pumping 1350 g.p.m. <input type="checkbox"/> ft. after <input type="checkbox"/> hrs. pumping <input type="checkbox"/> g.p.m. Estimated maximum yield <input type="checkbox"/> 1350 g.p.m. 13. Water sample submitted: <input type="checkbox"/> mo./day/yr. Yes <input type="checkbox"/> No <input type="checkbox"/> Date 14. Well head completion: 12 Pitless adapter <input type="checkbox"/> Inches above grade 15. Well grouted? <input checked="" type="checkbox"/> yes With: <input type="checkbox"/> Neat cement <input type="checkbox"/> Bentonite <input type="checkbox"/> Concrete Depth: From 0 ft. to 10 ft. 16. Nearest source of possible contamination: N/A ft. <input type="checkbox"/> Direction <input type="checkbox"/> Type <input type="checkbox"/> Well disinfected upon completion? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No 17. Pump: Not installed Manufacturer's name Peerless FMC Model number 121B HP 100 Volts <input type="checkbox"/> Length of drop pipe 140 ft. capacity <input type="checkbox"/> 1000 g.p.m. Type: <input type="checkbox"/> Submersible <input checked="" type="checkbox"/> Turbine <input type="checkbox"/> Jet <input type="checkbox"/> Reciprocating <input type="checkbox"/> Centrifugal <input type="checkbox"/> Other 18. Elevation: Topography: <input type="checkbox"/> Hill <input checked="" type="checkbox"/> Slope <input type="checkbox"/> Upland <input type="checkbox"/> Valley 19. Remarks: Drilling done by Central Well and Pump (Honomichl)				

The Professionals MINTER-WILSON DRILLING CO.
INCORPORATED

Irrigation
and Domestic
Water Systems
Complete Installation
and Repairing

Phone 276-8269 • P.O. Box 493 • GARDEN CITY, KANSAS 67846

DON MILLERSASKI
GRAY COUNTY
2-17-76

LOCATION: SW 23-26-29
South Of Ingalls, Right 3½ Mile, South ¼,
East 2/10, South 30 Feet West Of Pivot

STATIC WATER LEVEL: 70

TEST #

0	5	Top Soil
5	15	Brown Sandy Clay
15	23	Fine To Med. Sand
23	48	Brown Sandy Clay
48	65	Fine To Med. Sand & Gravel
65	173	Coarse Gravel
173	186	Fine To Med. Sand & Gravel 10% Clay
186	216	Med. To Coarse Gravel Mixed With Yellow & White Rock
216	233	Brown Sandy Clay
233	241	Yellow Clay Mixed With Rock (hard)
241	241	Shale

TD 216 20 Screen

110' Plain
50' Perf
10' Screen
20' Perf.
10' Screen
16' Perf.